

Appendix E – Worksheets for Major Sources of PM10, NOx and SO2

Regulation No. 1

Particulates, Smokes, Carbon Monoxide and Sulfur Oxides

Colorado Air Quality
Control Commission



Colorado Department
of Public Health
and Environment

7. Fort Carson shall maintain records of each fog oil smoke generation exercise which shall include:
 - a. observations from the designated observer(s) regarding the drift of the fog oil smoke only when said smoke approaches the Installation or Site boundary to the extent that all generation must cease to prevent visible emissions from crossing the boundary;
 - b. the amount of fog oil used in gal/day;
 - c. the general location at which the fog oil smoke was generated; and
 - d. the date and duration of the fog oil smoke generation; and
8. For purposes of this section, fog oil is defined as highly refined (hydro-treated) virgin oil.

The Commanding General in charge of Fort Carson shall be responsible for ensuring that no drift of smoke from fog oil generation or other obscurant use occurs across the boundary of the military reservations, even if generated in accordance with this section.

III. PARTICULATES

A. Fuel Burning Equipment

1. No owner or operator shall cause or permit to be emitted into the atmosphere from any fuel-burning equipment, particulate matter in the flue gases which exceeds the following:
 - a. 0.5 lbs. per 10⁶ BTU heat input for fuel burning equipment of less than or equal to 1x10⁶ BTU/hr. total heat input design capacity.
 - b. For fuel burning equipment with designed heat inputs greater than 1x10⁶ BTU per hour, but less than or equal to 500x10⁶ BTU per hour, the following equation will be used to determine the allowable particulate emission limitation.

$$PE=0.5(FI)^{0.26}$$

Where:

PE = Particulate Emission in Pounds per million BTU heat input.

FI = Fuel Input in Million BTU per hour.
 - c. 0.1 lbs. per 10⁶ BTU heat input for fuel burning equipment of greater than 500x10⁶ BTU per hour or more.

- d. If two or more fuel burning units connect to any opening, the maximum allowable emission rate shall be calculated by summing the allowable emissions from the units being operated.

2. Exceptions

Sources and emissions subject to the emission limitation of Section V. of this regulation.

3. Performance Tests

Prior to granting of a final approval permit or amending a permit, when an emission source or control equipment is altered, or at any time when there is reason to believe that emission standards are being violated, the Division may require the owner or operator of any fuel burning equipment to conduct performance tests, as measured by EPA Methods 1-4 and the front half of EPA Method 5 (40 CFR 60.275, Appendix A, Part 60) to determine compliance with this subsection of this regulation.

- B. Incinerators

1. No owner or operator of an incinerator shall operate any incinerator without a permit from the Division.

2. Standard of Performance for all incinerators other than biomedical waste incinerators.

- a. In areas designated as nonattainment for particulate matter, no owner or operator of an incinerator shall cause or permit emissions of more than 0.10 grain of particulate matter per standard cubic foot. (Dry flue gas corrected to 12 percent carbon dioxide.)
- b. In areas designated as attainment for particulate matter, no owner or operator of an incinerator shall cause or permit emissions of more than 0.15 grain of particulate matter per standard cubic foot. (Dry Flue gas corrected to 12 percent carbon dioxide.)

3. Performance Tests

Prior to granting a final approval permit or amending a permit, when an emission source or control equipment is altered, or at any time when there is reason to believe that emission standards are being violated, the Division may require the owner or operator of an incinerator to conduct performance tests(s) in accordance with Appendix A of Air Quality Control Commission Regulation Number 6.

4. Standard of Performance for Biomedical Waste Incinerators.

The owner or operator of an existing incinerator used for the disposal of biomedical waste shall comply with Regulation No. 6, Part B. V. Standard of Performance For New Biomedical Waste Incinerators as follows:

- a. All incinerators, existing as of the effective date of Regulation 6 Part B, V., with a design capacity of 400 pounds per hour and greater must comply with the requirements of this regulation by January 1, 1990.
- b. All incinerators, existing as of the effective date of Regulation 6, Part B, V., with a design capacity of less than 400 pounds per hour must comply with the requirements of this regulation as applicable by December 31, 1994; except incinerators with a design capacity of less than 200 pounds per hour shall be permitted and allowed to operate only so long as the units continue to meet the particulate and visible emission standards existing prior to the effective date of Regulation 6, Part B.V., the manufacturer's design specifications and any other applicable safety standards. (The standards existing prior to the effective date of this regulation are: a) For sources existing prior to January 30, 1979: 20% opacity and 0.10 grains of particulate matter (PM) for particulate matter non-attainment areas and 0.15 grains of PM for PM attainment areas; b) 20% opacity and 0.10 grains of PM for sources constructed after January 30, 1979.)

C. Manufacturing Processes

1. Except as provided in paragraphs 2 and 3 of this subsection C., no owner or operator of a manufacturing process unit shall cause or permit emission of any particulate matter into the atmosphere during any consecutive sixty (60) minute period which is in excess of the following.
 - a. For process equipment having process weight rates of 30 tons per hour or less, the allowable emission rate shall be determined by the use of the equation:
- b. For process equipment having process weight rates of greater than 30 tons per hour, the allowable emission rate shall be determined by use of the equation:

$$PE = 3.59(P)^{0.62}$$

Where:

PE = Particulate Emission in lbs. per hour

P = Process weight rate in tons per hour

$$PE = 17.31(P)^{0.16}$$

Where:

PE = Particulate Emission rate in lbs. per hour

P = Process weight rate in tons per hour

- c. If two or more process units are connected to the same opening, the maximum allowable emission rate shall be computed by summing the allowable emissions for the units being operated.

2. Alfalfa Dehydration Plant Drum Dryers

New alfalfa dehydration plants shall be subject to the provisions of III.C. of this regulation for process weight rates.

3. Exceptions

- a. Sources and emissions subject to the emission limitations of Section V. of this regulation.
- b. Fugitive dust and fugitive particulate emissions as defined in Section II.A.8 of this Regulation.

- 4. Performance Tests: prior to granting of a final approval permit or amending a permit, when an emission source or control equipment is altered, or at any time when there is reason to believe that emission standards are being violated, the Division may require the owner or operator of any manufacturing process to conduct performance tests, as measured by EPA Methods 1-4 and the front half of EPA Method 5 (40 CFR 60.275, Appendix A, Part 60) to determine compliance with this subsection of this regulation.

D. Fugitive Particulate Emissions

1. General Requirements

a. Existing Sources

- (i) Every owner or operator of a source or activity which is subject to this Section III.D. shall employ such control measures and operating procedures as are necessary to minimize fugitive particulate emissions into the atmosphere through the use of all available practical methods which are technologically feasible and economically reasonable and which reduce, prevent and control emissions so as to facilitate the achievement of the maximum practical degree of air purity in every portion of the State.
- (ii) In determining what control methods are available, practical, economically reasonable and technologically feasible, the following factors shall be considered: effects on the health, welfare (as defined in Section I.G. of the Common Provisions regulation), convenience, and comfort of the inhabitants of the

- (A) For process equipment having process weight rates of up to thirty (30) tons per hour, the allowable emission rate shall be determined by the use of the equation:

$$PE = 3.59(P)^{0.62}$$

Where:

PE = Particulate emission in lbs. per hour

P = Process weight rate in ton per hour

- (B) For process equipment having process weight rates of greater than thirty (30) tons per hour, the allowable emission rate shall be determined by use of the equation:

$$PE = 17.31(P)^{0.16}$$

Where:

PE = Particulate emission rate in lbs. per hour

P = Process weight rate in tons per hour

- (C) If two or more process units are connected to the same opening, the maximum allowable emission rate shall be computed by summing the individual emissions rates.

(ii) Performance Tests

Prior to granting or amending a permit, when an emission source or control equipment is altered, or at any time when there is reason to believe that emission standards are being violated, the Division may require the owner or operator of an existing manufacturing process to conduct performance test(s) as measured by EPA Methods (1-4) and the front half of EPA Method 5 (40 CFR 60.275, Appendix A, Part 60) as may be amended to determine compliance with this subsection of this regulation.

- G. A statement of the basis and purpose for the revisions to this Section V., adopted March 11, 1982 is hereby incorporated by reference, and a copy of the statement is available from the Air Quality Control Commission office.

VI. SULFUR DIOXIDE EMISSION REGULATIONS

A. Sources constructed or modified prior to August 11, 1977 shall be considered an existing source. All existing sources of sulfur dioxide emissions, except for sources listed in Section VII, shall comply with the following:

1. Averaging time - Unless otherwise specified in other sections of this regulation, the averaging time for all sulfur dioxide emissions standards for sources which utilize a CEM shall be a three hour rolling average and the frequency of fuel sampling for sources which utilize a fuel sampling plan approved pursuant to Section IV.B.2. shall be as specified in such plan.
2. If the sum of sulfur dioxide emission rates for all sources located on a contiguous site is less than three (3) tons per day potential uncontrolled SO₂ emissions, and if all Federal and State Ambient Air Quality Standards are met no process based SO₂ emission standard shall apply.
3. Existing sources of sulfur dioxide shall not emit sulfur dioxide in excess of the following process-specific limitations. (Heat input rates shall be the manufacturer's guaranteed maximum heat input rates).

a. Coal-fired operations including coal-fired steam generation:

(These standards are also applicable to the use of coal-based by-product fuels.)

(i) Units with a heat input from coal or coal-based by-product fuels of less than 300 million BTU per hour:

1.8 pounds of sulfur dioxide per million BTU of heat input.

(ii) Units with a heat input from coal or coal-based by-product fuels equal to or greater than 300 million BTU per hour:

1.2 pounds of sulfur dioxide per million BTU of heat input.

b. Oil-fired Operations Including Oil-Fired Steam Generation

(i) Units with a heat input from oil of less than 300 million BTU per hour:

1.5 pounds of sulfur dioxide per million BTU of heating input.

(ii) Units with a heat input from oil equal to or greater than 300 million BTU per hour:

0.8 pounds of sulfur dioxide per million BTU of heating input.

c. Combustion Turbines

- (i) Combustion Turbines with a heat input of less than 300 million BTU per hour:

1.2 pounds of sulfur dioxide per million BTU of heating input.

- (ii) Combustion Turbines with a heat input equal to or greater than 300 million BTU per hour:

0.8 pounds of sulfur dioxide per million BTU of heating input.

d. Natural Gas Desulfurization

Desulfurization Plants emitting more than five (5) tons of sulfur dioxide per day:

2 pounds of sulfur dioxide per 1,000 cubic feet of (Actual) delivered gas.

e. Petroleum Refining

0.7 pounds sulfur dioxide for the sum of all SO₂ emissions from a given Refinery, per barrel of oil processed, per day. This emission limit shall be calculated over each 24 hour period which commences at midnight. If the refinery does not operate for the entire 24 hour period, the actual hours of operation shall be used as the averaging time. At no time shall the averaging time be greater than 24 hours. Refineries in operation on or before August 1, 1995, which are covered by this regulation, shall submit a plan for Division approval no later than February 1, 1996. Sources constructed after August 1, 1995 shall submit a plan for Division approval along with construction permit applications. The plan shall define how compliance with this limitation will be demonstrated. This plan shall address both how the SO₂ value is calculated, i.e. mass balance, monitors, and how the barrels of oil processed value is derived, taking into account intermediate storage. The Division shall not limit the determination of barrels processed per day to a 24 hour period.

All data used to show compliance with this emission standard shall be maintained by the owner or operator of the affected source for a period of two (2) years for sources that are not subject to the operating permit program, and five (5) years for sources that are subject to the operating permit program. This data shall be available for inspection by the Division upon request.

f. Cement Manufacture

abrogate the Commission's or Division's authority to require testing under Article 7 of Title 25, Colorado Revised Statute 1973, and regulations of the Commission promulgated thereunder.

3. The owner or operator of an affected facility shall provide the Division thirty (30) days prior notice of the performance test to afford the Division the opportunity to have an observer present.

E. Related Compounds Containing Sulfur in Oxidized States:

1. For the purposes of this regulation, all oxidized forms of sulfur (including, but not restricted to sulfur trioxide (SO₃), trionyl chloride (SOCl₂), and sulfuric acid mist (H₂SO₄)) shall be considered as sulfur dioxide.
2. Quantities of such oxidized sulfur compounds shall be converted on a molar basis to an equivalent quantity of sulfur dioxide. The total of all such quantities, (expressed in parts per million by volume sulfur-dioxide-equivalents of other oxidized forms) shall be interpreted as "parts per million by volume sulfur dioxide" as used in Section B. above.

F. Alternative Compliance Procedures

1. Any person may apply to the Division Director for approval of an alternative:
 - a. Test method,
 - b. Method of control,
 - c. Compliance period,
 - d. Emission limit, or
 - e. Monitoring schedule.
2. The application shall include a demonstration that the proposed alternative produces:
 - a. An equal or greater air quality benefit than that required in this subsection VI, or
 - b. The alternative test method is equivalent to that required by these regulations.
3. The Division Director shall obtain concurrence from EPA prior to approving an alternative.

VII. EMISSION REGULATIONS FOR CERTAIN ELECTRIC GENERATING STATIONS OWNED AND OPERATED BY THE PUBLIC SERVICE COMPANY OF COLORADO

A. The electric generating stations owned and operated by the Public Service Company of Colorado listed below shall not emit or cause to be emitted nitrogen oxides (NO_x) or sulfur dioxide (SO₂) in excess of the following limits. The emission rates for NO_x and SO₂ are measure in terms of pounds of pollutant per million British Thermal Units of fuel fired in the unit (lb/mmBTU).

1. Cherokee Electric Generating Station, 6198 North Franklin Street, Denver, CO

	NO _x (lb/mmBTU)	SO ₂ (lb/mmBTU)
Unit 1	-	1.1
Unit 2	-	1.1
Unit 3	0.60	1.1
Unit 4	0.45	1.1

- The NO_x limit will be calculated based on a 30-day rolling average, and is effective November 1, 1994.
- The SO₂ limit will be calculated as a three-hour rolling average, and is effective November 1, 1994.
- Public Service Company of Colorado shall install, certify and operate continuous emission monitoring equipment for measuring opacity, SO₂, NO_x, and either O₂ or CO₂ on Units 1, 2, 3 and 4 no later than January 1, 1995.

2. Arapahoe Electric Generating Station, 2601 South Platte River Drive, Denver, CO

	NO _x (lb/mmBTU)	SO ₂ (lb/mmBTU)
Unit 1	-	1.1
Unit 2	-	1.1
Unit 3	-	1.1
Unit 4	.60	1.1 +20% annual tonnage reduction

- The NO_x limit will be calculated based on a 30-day rolling average, and is effective November 1, 1994.
- The SO₂ limit will be calculated as a three-hour rolling average, and is effective January 1, 1995.

- The 20% SO₂ limit from Unit 4 shall be calculated on a calendar year, total annual tonnage basis. SO₂ removal Equipment shall be continuously operated from November 1 to March 1 of each year, except during periods of upset conditions or because of unavoidable circumstances that render the equipment inoperable. If at any time between November 1 and March 1 of any year the equipment is not operated for a period of 24 hours or longer, Public Service Company of Colorado shall report the event to the Division in accordance with the Common Provisions Regulation.
- Public Service Company of Colorado shall install, certify and operate continuous emission monitoring equipment for measuring opacity, SO₂, NO_x, and either O₂ or CO₂ on Units 1, 2, 3 and 4 no later than January 1, 1995.

3. Valmont Electric Generating Station, 1800 North 63rd Street, Boulder, CO

	NO _x (lb/mmBTU)	SO ₂ (lb/mmBTU)
Unit 5	0.45	1.1

- The NO_x limit will be calculated based on a 30-day rolling average, and is effective November 1, 1994.
- The SO₂ limit will be calculated as a three-hour rolling average, and is effective November 1, 1994.
- Public Service Company of Colorado shall install, certify and operate continuous emission monitoring equipment for measuring opacity, SO₂, NO_x, and either O₂ or CO₂ on Units 1, 2, 3 and 4 no later than January 1, 1995.

- B. Public Service Company of Colorado shall submit to the Division for approval, no later than June 30, 1994, the procedure to be used for the measurement and calculation of the emission averages and emission reductions from these electric generating stations.

VIII. RESTRICTIONS ON THE USE OF OIL AS A BACKUP FUEL

A. Applicability

The provisions of this section are applicable to all points at the following stationary sources in the Denver PM10 nonattainment area that use oil as a backup fuel for natural gas, which is the primary process fuel:

1. Public Service Company of Colorado, Zuni Electric Generating Station;
2. Public Service Company of Colorado, Valmont Electric Generating Station;
3. Public Service Company of Colorado, Delgany Steam Generating Station;
4. Fitzsimmons Army Medical Center;

5. US Department of Energy, Rocky Flats Plant;
6. Gates Rubber Company; and
7. Coors Brewing Company, Coors Brewery, Golden, CO.

B. Requirements

Beginning November 1, 1993, natural gas shall be the only fuel used from November 1 to March 1 of each year, except under the following circumstances:

1. the supplier of transporter or natural gas imposes a curtailment or an interruption of service;
2. for necessary testing of equipment used to operate the unit on oil, testing of fuel and training of personnel; or
3. when an equipment malfunction at the facility makes it impossible or unsafe for the unit to operate on natural gas.

C. Recordkeeping

Each stationary source subject to the provisions shall maintain records for a period of two years which include the following information:

1. dates and number of hours fuel oil is burned;
2. percent sulfur analysis of the fuel oil that is burned;
3. number of gallons burned each day; and
4. reason(s) for the use of the fuel oil.

D. Reporting

Beginning April 1, 1994 and by April 1 of each year thereafter, each stationary source subject to these provisions shall submit to the division a report containing the information listed in Section VIII.C.

E. Alternate Recordkeeping and Reporting

Where the information required under subsections C and D above is otherwise made available to the Division, for example in EIS reports submitted by the source or pursuant to operating permit requirements, the requirements of subsections C and D of this Section VIII are satisfied.

IX. EMISSION REGULATIONS CONCERNING AREAS WHICH ARE NONATTAINMENT FOR CARBON MONOXIDE - REFINERY FLUID BED CATALYTIC CRACKING UNITS:

Appendix E.2 T5 Emission Factors

2002 Maximum Allowable Emissions
Major NOx, SO2 & PM10 Sources

Source	Maximum Operation				SO2				NOx				PM10			
	Design Rate mmBtu/hr	hr/yr	Emission Limit ton/lb lb/mmBtu	Control Efficiency (%)	Emission Rate (t/yr)	Emission Rate (lb/hr)	Emission Rate (tons/day)	Emission Limit lb/mmBtu	Emission Rate (t/yr)	Emission Rate (lb/hr)	Emission Rate (tons/day)	Emission Limit lb/mmBtu	Fraction PM10 of PM	Emission Rate (t/yr)	Emission Rate (lb/hr)	Emission Rate (tons/day)
Cherokee																
Unit 1	1392	8760	0.0005	1.1	5,365	1,225	14.7	0.96	5,853	1,336	16.0	0.1	0.92	561	128	1.5
Unit 2	1392	8760	0.0005	1.1	6,707	1,531	18.4	0.96	5,853	1,336	16.0	0.1	0.92	561	128	1.5
Unit 3	1877	8760	0.0005	1.1	9,043	2,065	24.8	0.60	4,933	1,126	13.5	0.1	0.92	756	173	2.1
Unit 4	3520	8760	0.0005	1.1	13,567	3,098	37.2	0.45	6,938	1,584	19.0	0.1	0.92	1,418	324	3.9
TOTAL					34,683	7,918	95.0		23,577	5,383	64.6			3,297	753	9.0
Arapahoe																
Unit 1	754.8	8760	0.0005	1.1	3,637	830	10.0	0.98	3,240	740	8.9	0.1	0.67	222	51	0.6
Unit 2	754.8	8760	0.0005	1.1	3,637	830	10.0	0.98	3,240	740	8.9	0.1	0.67	222	51	0.6
Unit 3	754.8	8760	0.0005	1.1	3,637	830	10.0	0.98	3,240	740	8.9	0.1	0.92	304	69	0.8
Unit 4	1709.0	8760	0.0005	1.1	6,587	1,504	18.0	0.6	4,491	1,025	12.3	0.1	0.92	689	157	1.9
2 Turbines (2002)					0.5*	0.4	0.0	0.0	39*	62	0.7			8*	6	0.1
TOTAL					17,498	3,995	47.9		14,250	3,307	39.7			1,444	334	4
Valmont																
Unit 5	1845	8760	0.0005	1.1	8,899	2,030	24.4	0.45	3,636	830	10.0					
Unit 6	570	8760	0.0005	0.0006	1	0.4	0.0	0.32	799	182	2.2					
2 Turbine (2002)					0.5*	0.4	0.0	0.0	39*	61	0.7					
TOTAL					8,891	2,030	24.4		4,474	1,074	12.9					
Trigen																
Boiler 1 (gas)	288	8760	0.0005	0.0006	1	0	0.0	0.28	353	81	1.0	0.11		139	32	0.4
Boiler 2 (gas)	225	8760	0.0005	0.0006	1	1,774	405	4.9	384	88	1.1	0.12		139	32	0.4
Boiler 3	360	8760	0.0005	1.8	1,892	432	5.2	0.7	1,104	252	3.0	0.10		118	27	0.3
Boiler 4	650	8760	0.0005	1.2	3,416	780	9.4	0.7	1,993	455	5.5	0.10		156	36	0.4
SIP reduction					-125	-29	-0.3		-225	-51	-0.6			285	65	0.8
TOTAL					6,959	1,569	19.1		3,962	905	10.9			836	191	2.3
Rocky Mtn. Boflle																
PTE by stack test					369	84	1.0		424	97	1.2					
TOTAL					369	84	1.0		424	97	1.2					
Conoco Refinery																
FCCU**	20,000	8760	0.0005											185.4	42	0.5
See attachment														41	9	0.1
TOTAL														226	52	0.6
UDS Refinery																
See attachment	5,769	8760	0.0005											200	46	0.5
TOTAL														241	55	0.7
Robinson Brick																
Rotary Dryer	357	8760	0.0005											32	7	0.1
Tunnel Dryer (2)	Reg. 1 Limit	8760	0.0005											130.8*	18	0.2
Rotary Catcher	10 tons/hr	8760	0.0005											22	5	0.1
TOTAL														166	30	0.4

* Annual Permit Limits, pile emissions modeled at maximum hourly emissions rate

** FCCU feed Rate-Barrels per day-Emissions Rate lbs PM10/1000 barrels and total pile emissions calculation by source

*** Total pile emissions calculation by Source

NOTE: This revision includes pile calculations for Cherokee 1-2, Arapahoe 1-3, Trigen 3 and RMB for NOx and RMB for SO2. Also, addition of Valmont 6.

2003 Maximum Allowable Emissions
Major NOx, SO2 & PM10 Sources

Source	Maximum Operation				SO2				NOx				PM10				
	Design Rate mmBtu/hr	hr/yr	ton/yr	Emission Limit lb/mmBtu	Control Efficiency (%)	Emission Rate (tpy)	Emission Rate (lb/hr)	Emission Rate (tons/day)	Emission Limit lb/mmBtu	Emission Rate (tpy)	Emission Rate (lb/hr)	Emission Rate (tons/day)	Reg. 1 Emission Limit lb/mmBtu	Fraction PM10 of PM	Emission Rate (tpy)	Emission Rate (lb/hr)	Emission Rate (tons/day)
Cherokee																	
Unit 1	1392	8760	0.0005	1.1	20	5,365	1,226	14.7	0.96	13,361	13,361	16.0	0.1	0.92	561	128	1.5
Unit 2	1892	8760	0.0005	1.1	0	6,707	1,531	18.4	0.96	5,853	13,361	16.0	0.1	0.92	561	128	1.5
Unit 3	1877	8760	0.0005	1.1	0	9,043	2,065	24.8	0.60	6,933	11,266	13.5	0.1	0.92	756	173	2.1
Unit 4	3520	8760	0.0005	1.1	20	13,667	3,098	37.2	0.45	6,938	15,941	19.0	0.1	0.92	1,418	324	3.9
TOTAL						34,663	7,916	95.0		23,577	5,303	64.5			3,297	753	9.0
Arapahoe																	
Unit 1 (ret. by 1/1/03)	754.8			1.1	0				0.98				0.1	0.67			
Unit 2 (ret. by 1/1/03)	754.8			1.1	0				0.98				0.1	0.67			
Unit 3	754.8	8760	0.0005	1.1	0	3,637	830	10.0	0.98	3,240	740	8.9	0.1	0.92	304	69	0.8
Unit 4	1709.0	8760	0.0005	1.1	20	6,597	1,504	18.0	0.6	4,491	10,251	12.3	0.1	0.92	689	157	1.9
2 Turbines (2002)						0.5*	0.4	0.0	0.0	39*	62	0.7			8*	6	0.1
TOTAL						10,224	2,335	28.0		7,770	1,827	21.9			1,001	233	2.8
Valmont																	
Unit 5	1845	8760	0.0005	1.1	0	8,889	2,030	24.4	0.45	3,636	830	10.0					
Unit 6	570	8760	0.0005	0.0006		1	0.4	0.0	0.32	798	182	2.2					
2 Turbine (2002)						0.5*	0.4	0.0	0.0	39*	61	0.7					
TOTAL						8,891	2,030	24.4		4,474	1,074	12.9					
Trigen																	
Boiler 1 (gas)	288	8760	0.0005	0.0006		1	0	0.0	0.28	353	81	1.0	0.11		139	32	0.4
Boiler 2 (gas)	288	8760	0.0005	0.0006		1	0	0.0	0.28	353	81	1.0	0.11		139	32	0.4
Boiler 3	225	8760	0.0005	1.8		1,774	405	4.9	0.4	384	88	1.1	0.12	1	118	27	0.3
Boiler 4	360	8760	0.0005	1.2		1,892	432	5.2	0.7	1,104	252	3.0	0.10	1	158	36	0.4
Boiler 5	650	8760	0.0005	1.2		3,416	780	9.4	0.7	1,993	455	5.5	0.1	1	285	65	0.8
SIP reduction						-125	-29	-0.3		-225	-51	-0.6					
TOTAL						6,959	1,559	19.1		3,962	905	10.9			838	191	2.3
Rocky Mtn. Bottle																	
PTE by stack test						369	84	1.0		424	97	1.2					
TOTAL						369	84	1.0		424	97	1.2					
Conoco Refinery													lb/barrel	Em. Factor	185.4	42	0.5
See attachment															41	9	0.1
TOTAL															226	52	0.5
UDS Refinery													lb/b Coke	Em. Factor	200	46	0.5
See attachment															42	9	0.1
TOTAL															241	55	0.7
Robinson Brick													lbs PM/hr				
Rotary Dryer	55	8760	0.0005										30.57	0.24	32	7	0.1
Tunnel Dryer (2)	10	8760	0.0005										17.9	1	131*	18	0.2
Rotary Calciner	10	8760	0.0005										14.97	0.34	22	5	0.1
TOTAL															165	30	0.4

* Annual Permit Limits; ple emissions modeled at maximum hourly emissions rate
 ** FCCU feed Rate-Barrels per day-Emissions Rate lbs PM10/1000 barrels and total ple emissions calculation by source
 *** Total ple emissions calculation by Source
 NOTE: This revision includes ple calculations for Cherokee 1-2, Arapahoe 1-3, Trigen 1-3, and RMB for SO2. Also, addition of Valmont 6.

**2005 Maximum Allowable Emissions
Major NOx, SO2 & PM10 Sources**

Source	Maximum Operation				SO2				NOx				PM10			
	Design Rate mmBtu/hr	hr/yr	Emission Limit lb/mmBtu	Control Efficiency (%)	Emission Rate Rate (tpy)	Emission Rate (tons/day)	Emission Limit lb/mmBtu	Emission Rate Rate (tpy)	Emission Rate (lb/hr)	Emission Rate (tons/day)	Emission Limit lb/mmBtu	Emission Rate Rate (tpy)	Fraction PM10 of PM	Emission Rate (lb/hr)	Emission Rate (tons/day)	
Cherokee																
Unit 1	1392	8760	0.0005	1.1	20	5,365	1,225	14.7	0.60	3,658	835	0.1	561	128	1.5	
Unit 2	1392	8760	0.0005	1.1	0	6,707	1,531	16.4	0.96	5,853	1336	0.1	561	128	1.5	
Unit 3	1877	8760	0.0005	1.1	0	9,043	2,065	24.8	0.60	4,933	1126	0.1	561	128	2.1	
Unit 4	3520	8760	0.0005	1.1	20	13,567	3,098	37.2	0.45	6,938	1584	0.1	561	128	3.9	
TOTAL						34,683	7,918	95.0		21,382	4,882		3,297	753	9.0	
Arapahoe																
Unit 1 (ret. by 1/1/03)	754.8		0.0005	1.1	0				0.98			0.1				
Unit 2 (ret. by 1/1/03)	754.8		0.0005	1.1	0				0.98			0.1				
Unit 3	754.8	8760	0.0005	1.1	0	3,637	830	10.0	0.98	3,240	740	0.1	304	69	0.8	
Unit 4	1709.0	8760	0.0005	1.1	20	6,587	1,504	18.0	0.6	4,491	1025	0.1	689	157	1.9	
2 Turbines (2002)		8760	0.0005	1.1		0.5*	0.4	0.0	0.6	39*	62	0.1	8*	6	0.1	
TOTAL						10,224	2,335	28.0		7,770	1,827		1,001	233	2.8	
Valmont																
Unit 5	1845	8760	0.0005	1.1	0	8,869	2,030	24.4	0.45	3,636	830					
Unit 6	570	8760	0.0005	0.0006		1	0	0.0	0.32	799	182					
2 Turbine (2002)		8760	0.0005	0.0005		0.5*	0.4	0.0	0.0	39*	61					
TOTAL						8,891	2,030	24.4		4,474	1,074					
Trigen																
Boiler 1 (gas)	286	8760	0.0005	0.0006		1	0	0.0	0.28	353	81		139	32	0.4	
Boiler 2 (gas)	226	8760	0.0005	0.0006		1	0	0.0	0.28	353	81		139	32	0.4	
Boiler 3	226	8760	0.0005	1.8		1,774	405	4.9	0.4	384	88		116	27	0.3	
Boiler 4	360	8760	0.0005	1.2		1,892	432	5.2	0.7	1,104	252		158	36	0.4	
Boiler 5	650	8760	0.0005	1.2		3,416	780	9.4	0.7	1,993	455		285	65	0.8	
SIP reduction			0.0005			-125	-29	-0.3		226	-51					
TOTAL						6,959	1,589	19.1		3,962	905		836	191	2.3	
Rocky Mtn. Bottle																
PTE by stack test																
TOTAL																
Conoco Refinery																
FCCU**	20,000	8760	0.0005			369	84	1.0		424	97					
See attachment		8760	0.0005			369	84	1.0		424	97					
TOTAL																
UDS Refinery																
FCCU***	5,789	8760	0.0005													
See attachment		8760	0.0005													
TOTAL																
Robinson Brick																
Rotary Dryer	357 Tons/Hr	8760	0.0005													
Tunnel Dryer (2)	Reg. 1 Limit	8760	0.0005													
Rotary Calciner	10 Tons/Hr	8760	0.0005													
TOTAL																

* Annual Permit Limits, pie emissions modeled at maximum hourly emissions rate
 ** FCCU feed Rate-Barrels per day-Emissions Rate lbs.PM10/1000 Barrels and total pie emissions calculation by source
 *** Total pie emissions calculation by Source

NOTE: This revision includes pie calculations for Cherokee 1-3, Trigen 3 and RMB for SO2. Also, addition of Valmont 6 and 0.6 lb Nox/mmBtu at Cherokee 1

MAXIMUM ALLOWABLE EMISSIONS

Public Service Company - Zuni Station

Source	Design Rate (mmBtu/hr)	Reg. 1 Limit (lb/mmBtu)	Fraction PM10 of PM	Hours of Operation	ton/lb	Emission Rate (tpy)	Emission Rate (lb/hr)	Emission Rate (tpd)
Unit 1A (coal)	450	0.102	0.71	8760	0.0005	143	32.59	0.39
Unit 1B (coal)	200	0.126	0.71	8760	0.0005	78	17.89	0.21
Unit 2 (coal)	1075	0.1	0.71	8760	0.0005	334	76.33	0.92
Total						555	127	2

APCD staff included Zuni in the ISC modeling for major sources of PM10 and used the Regulation 1 emissions limit for combustion sources, which is fuel neutral. Regulation 1, however, includes a provision that requires Zuni to be operated on gas during the winter season; and a more appropriate calculation is included below. The ISC modeling indicates that at the emission rate calculated using the Regulation 1 limit above (555 tpy) has a negligible effect on receptor concentration. Additional ISC modeling with the more appropriate 56 tpy was considered unnecessary.

Source	Design Rate (mmBtu/hr)	Heat Value (scf/1000 Btu)	lbs. PM10/ mmscf	Hours of Operation	ton/lb	Emission Rate (tpy)	Emission Rate (lb/hr)	Emission Rate (tpd)
Unit 1A (gas)	450	0.001	7.45	8760	0.0005	15	3.35	0.04
Unit 1B (gas)	200	0.001	7.45	8760	0.0005	7	1.49	0.02
Unit 2 (gas)	1075	0.001	7.45	8760	0.0005	35	8.01	0.10
Total						56	13	0

Source	Design Rate (mmBtu/hr)	Heat Value (scf/1000 Btu)	lbs. NOx/ mmscf*	Hours of Operation	ton/lb	Emission Rate (tpy)	Emission Rate (lb/hr)	Emission Rate (tpd)
Unit 1A (gas)	450	0.001	280	8760	0.0005	552	126.00	1.51
Unit 1B (gas)	200	0.001	280	8760	0.0005	245	56.00	0.67
Unit 2 (gas)	1075	0.001	280	8760	0.0005	1318	301.00	3.61
Total						2116	483	5.80

* new AP-42 emission factor

Source	Design Rate (mmBtu/hr)	Heat Value (scf/1000 Btu)	lbs. SO2/ mmscf	Hours of Operation	ton/lb	Emission Rate (tpy)	Emission Rate (lb/hr)	Emission Rate (tpd)
Unit 1A (gas)	450	0.001	0.6	8760	0.0005	1	0.27	0.00
Unit 1B (gas)	200	0.001	0.6	8760	0.0005	1	0.12	0.00
Unit 2 (gas)	1075	0.001	0.6	8760	0.0005	3	0.65	0.01
Total						5	1	0

Prepared by Jerry Dilley

Appendix E.3 AP – 42 Emission Factors

Table 1.1-6. CUMULATIVE PARTICLE SIZE DISTRIBUTION AND SIZE-SPECIFIC EMISSION FACTORS FOR DRY BOTTOM BOILERS BURNING PULVERIZED BITUMINOUS AND SUBBITUMINOUS COAL^a

Particle Size ^b (µm)	Cumulative Mass % ≤ Stated Size						Cumulative Emission Factor ^c (lb/ton)			
	Uncontrolled	Controlled			Uncontrolled ^d	Controlled ^e			ESP ^g	Baghouse ^f
		Multiple Cyclones	Scrubber	ESP		Multiple Cyclones ^f	Scrubber ^g	ESP ^g		
15	32	54	81	79	97	3.2A	1.08A	0.48A	0.064A	0.02A
10	23	29	71	67	92	2.3A	0.58A	0.42A	0.054A	0.02A
6	17	14	62	50	77	1.7A	0.28A	0.38A	0.024A	0.02A
2.5	6	3	51	29	53	0.6A	0.06A	0.3A	0.024A	0.01A
1.25	2	1	35	17	31	0.2A	0.02A	0.22A	0.01A	0.006A
1.00	2	1	31	14	25	0.2A	0.02A	0.18A	0.01A	0.006A
0.625	1	1	20	12	14	0.10A	0.02A	0.12A	0.01A	0.002A
TOTAL	100	100	100	100	100	10A	2A	0.6A	0.08A	0.02A

^a Reference 33. Applicable Source Classification Codes are 1-01-002-02, 1-02-002-02, 1-03-002-06, 1-01-002-12, 1-02-002-12, and 1-03-002-16. To convert from lb/ton to kg/Mg, multiply by 0.5. Emission Factors are lb of pollutant per ton of coal combusted, as fired. ESP =

Electrostatic precipitator.

^b Expressed as aerodynamic equivalent diameter.

^c A = coal ash weight percent, as fired. For example, if coal ash weight is 8.2%, then A = 8.2.

^d EMISSION FACTOR RATING = C.

^e Estimated control efficiency for multiple cyclones is 80%; for scrubber, 94%; for ESP, 99.2%; and for baghouse, 99.8%.

^f EMISSION FACTOR RATING = E.

^g EMISSION FACTOR RATING = D.

Table 1.3-4. CUMULATIVE PARTICLE SIZE DISTRIBUTION AND SIZE-SPECIFIC EMISSION FACTORS FOR UTILITY BOILERS FIRING RESIDUAL OIL^a

Particle Size ^b (µm)	Cumulative Mass % ≤ Stated Size				Cumulative Emission Factor lb/10 ³ gal					
	Controlled		Uncontrolled ^c		ESP Controlled ^d			Scrubber Controlled ^e		
	Uncontrolled	ESP	Scrubber	Emission Factor	EMISSION FACTOR RATING	Emission Factor	EMISSION FACTOR RATING	Emission Factor	EMISSION FACTOR RATING	
15	80	75	100	6.7A	C	0.05A	E	0.50A	D	
10	71	63	100	5.9A	C	0.042A	E	0.50A	D	
6	58	52	100	4.8A	C	0.035A	E	0.50A	D	
2.5	52	41	97	4.3A	C	0.028A	E	0.48A	D	
1.25	43	31	91	3.6A	C	0.021A	E	0.46A	D	
1.00	39	28	84	3.3A	C	0.018A	E	0.42A	D	
0.625	20	20	64	1.7A	C	0.007A	E	0.32A	D	
TOTAL	100	100	100	8.3A	C	0.067A	E	0.50A	D	

^a Reference 26. Source Classification Codes 1-01-004-01/04/05/06 and 1-01-005-04/05. To convert from lb/10 gal to kg/m³, multiply by 0.120.

^b ESP = electrostatic precipitator.

^c Expressed as aerodynamic equivalent diameter.

^d Particulate emission factors for residual oil combustion without emission controls are, on average, a function of fuel oil grade and sulfur content where S is the weight % of sulfur in the oil. For example, if the fuel is 1.00% sulfur, then S = 1.

No. 6 oil: A = 1.12(S) + 0.37

No. 5 oil: A = 1.2

No. 4 oil: A = 0.84

^e Estimated control efficiency for ESP is 99.2%.

^f Estimated control efficiency for scrubber is 94%

Table 11.25-8. PARTICLE SIZE DISTRIBUTIONS FOR FIRE CLAY PROCESSING^a

EMISSION FACTOR RATING: D

Diameter (μm)	Uncontrolled	Multiclone Controlled	Cyclone Controlled	Cyclone/Scrubber Controlled
	Cumulative % Less Than Diameter	Cumulative % Less Than Diameter	Cumulative % Less Than Diameter	Cumulative % Less Than Diameter
Rotary Dryers (SCC 3-05-043-30) ^b				
2.5	2.5	ND	14	ND
6.0	10	ND	31	ND
10.0	24	ND	46	ND
15.0	37	ND	60	ND
20.0	51	ND	68	ND
Rotary Calciners (SCC 3-05-43-40) ^c				
1.0	3.1	13	ND	31
1.25	4.1	14	ND	43
2.5	6.9	23	ND	46
6.0	17	39	ND	55
10.0	34	50	ND	69
15.0	50	63	ND	81
20.0	62	81	ND	91

^a For filterable PM only. SCC = Source Classification Code. ND = no data.

^b Reference 11.

^c References 12-13 (uncontrolled). Reference 12 (multiclone-controlled). Reference 13 (cyclone/scrubber-controlled).

Table 1.1-3. UNCONTROLLED EMISSION FACTORS FOR SO_x, NO_x, AND CO FROM BITUMINOUS AND SUBBITUMINOUS COAL COMBUSTION^a

Firing Configuration	SCC	SO _x ^b		NO _x ^c		CO ^{d,e}	
		Emission Factor (lb/ton)	EMISSION FACTOR RATING	Emission Factor (lb/ton)	EMISSION FACTOR RATING	Emission Factor (lb/ton)	EMISSION FACTOR RATING
PC-fired, dry bottom, wall-fired	1-01-002-02/22	38S (35S)	A	21.7	A	0.5	A
	1-02-002-02/22						
	1-03-002-06/22						
PC-fired, bituminous coal, dry bottom, cell burner fired ^f	1-01-002-15	38S (35S)	A	31.1	C	0.5	A
	1-01-002-12/26						
	1-02-002-12/26						
PC-fired, dry bottom, tangentially fired	1-03-002-16/26	38S (35S)	A	14.4	A	0.5	A
	1-01-002-01/21						
	1-02-002-01/21						
PC-fired, wet bottom	1-03-002-05/21	38S (35S)	D	34.0	C	0.5	A
	1-01-002-03/23						
	1-02-002-03/23						
Cyclone furnace	1-03-002-03/23	38S (35S)	D	33.8	C	0.5	A
	1-01-002-04/24						
	1-02-002-04/24						
Spreader stoker	1-03-002-09/24	38S (35S)	B	13.7	A	5	A
	1-01-002-04/24						
	1-02-002-04/24						
Spreader stoker, with multiple cyclones, and reinjection	1-03-002-09/24	38S (35S)	B	13.7	A	5	A
	1-01-002-04/24						
	1-02-002-04/24						
Spreader stoker, with multiple cyclones, no reinjection	1-03-002-09/24	38S (35S)	A	13.7	A	5	A
	1-01-002-04/24						
	1-02-002-04/24						

Table 1.1-3 (cont.).

Firing Configuration	SCC	SO _x ^b		NO _x ^c		CO ₂ ^{d,e}	
		Emission Factor (lb/ton)	EMISSION FACTOR RATING	Emission Factor (lb/ton)	EMISSION FACTOR RATING	Emission Factor (lb/ton)	EMISSION FACTOR RATING
Cyclone Furnace, bituminous	1-01-002-03	38S	A	33	A	0.5	A
	1-02-002-03						
	1-03-002-03						
Cyclone Furnace, sub-bituminous	1-01-002-23	35S	A	17	C	0.5	A
	1-02-002-23						
	1-03-002-23						
Spreader stoker, bituminous	1-01-002-04	38S	B	11	B	5	A
	1-02-002-04						
	1-03-002-09						
Spreader Stoker, sub-bituminous	1-01-002-24	35S	B	8.8	B	5	A
	1-02-002-24						
	1-03-002-24						
Overfeed stoker ¹	1-01-002-05/25	38S (35S)	B	7.5	A	6	B
	1-02-002-05/25						
	1-03-002-07/25						
Underfeed stoker	1-02-002-06	31S	B	9.5	A	11	B
	1-03-002-08						
Hand-fed units	1-03-002-14	31S	D	9.1	E	275	E

Table 3.1-1. EMISSION FACTORS FOR NITROGEN OXIDES (NO_x) AND CARBON MONOXIDE (CO) FROM STATIONARY GAS TURBINES

Emission Factors ^a				
Turbine Type	Nitrogen Oxides		Carbon Monoxide	
Natural Gas-Fired Turbines ^b	(lb/MMBtu) ^c (Fuel Input)	Emission Factor Rating	(lb/MMBtu) ^c (Fuel Input)	Emission Factor Rating
Uncontrolled	3.2 E-01	A	8.2 E-02 ^d	A
Water-Steam Injection	1.3 E-01	A	3.0 E-02	A
Lean-Premix	9.9 E-02	D	1.5 E-02	D
Distillate Oil-Fired Turbines ^e	(lb/MMBtu) ^f (Fuel Input)	Emission Factor Rating	(lb/MMBtu) ^f (Fuel Input)	Emission Factor Rating
Uncontrolled	8.8 E-01	C	3.3 E-03	C
Water-Steam Injection	2.4 E-01	B	7.6 E-02	C
Landfill Gas-Fired Turbines ^g	(lb/MMBtu) ^h (Fuel Input)	Emission Factor Rating	(lb/MMBtu) ^h (Fuel Input)	Emission Factor Rating
Uncontrolled	1.4 E-01	A	4.4 E-01	A
Digester Gas-Fired Turbines ^j	(lb/MMBtu) ^k (Fuel Input)	Emission Factor Rating	(lb/MMBtu) ^k (Fuel Input)	Emission Factor Rating
Uncontrolled	1.6 E-01	D	1.7 E-02	D

^a Factors are derived from units operating at high loads (≥ 80 percent load) only. For information on units operating at other loads, consult the background report for this chapter (Reference 16), available at "www.epa.gov/ttn/chieft".

^b Source Classification Codes (SCCs) for natural gas-fired turbines include 2-01-002-01, 2-02-002-01, 2-02-002-03, 2-03-002-02, and 2-03-002-03. The emission factors in this table may be converted to other natural gas heating values by multiplying the given emission factor by the ratio of the specified heating value to this average heating value.

^c Emission factors based on an average natural gas heating value (HHV) of 1020 Btu/scf at 60°F. To convert from (lb/MMBtu) to (lb/10⁶ scf), multiply by 1020.

^d It is recognized that the uncontrolled emission factor for CO is higher than the water-steam injection and lean-premix emission factors, which is contrary to expectation. The EPA could not identify the reason for this behavior, except that the data sets used for developing these factors are different.

^e SCCs for distillate oil-fired turbines include 2-01-001-01, 2-02-001-01, 2-02-001-03, and 2-03-001-02.

^f Emission factors based on an average distillate oil heating value of 139 MMBtu/10³ gallons. To convert from (lb/MMBtu) to (lb/10³ gallons), multiply by 139.

^g SCC for landfill gas-fired turbines is 2-03-008-01.

^h Emission factors based on an average landfill gas heating value of 400 Btu/scf at 60°F. To convert from (lb/MMBtu), to (lb/10⁶ scf) multiply by 400.

^j SCC for digester gas-fired turbine is 2-03-007-01.

^k Emission factors based on an average digester gas heating value of 600 Btu/scf at 60°F. To convert from (lb/MMBtu) to (lb/10⁶ scf) multiply by 600.

Table 1.4-1. EMISSION FACTORS FOR NITROGEN OXIDES (NO_x) AND CARBON MONOXIDE (CO)
FROM NATURAL GAS COMBUSTION^a

Combustor Type (MMBtu/hr Heat Input) [SCC]	NO _x ^b		CO	
	Emission Factor (lb/10 ⁶ scf)	Emission Factor Rating	Emission Factor (lb/10 ⁶ scf)	Emission Factor Rating
Large Wall-Fired Boilers (>100) [1-01-006-01, 1-02-006-01, 1-03-006-01]				
Uncontrolled (Pre-NSPS) ^c	280	A	84	B
Uncontrolled (Post-NSPS) ^c	190	A	84	B
Controlled - Low NO _x burners	140	A	84	B
Controlled - Flue gas recirculation	100	D	84	B
Small Boilers (<100) [1-01-006-02, 1-02-006-02, 1-03-006-02, 1-03-006-03]				
Uncontrolled	100	B	84	B
Controlled - Low NO _x burners	50	D	84	B
Controlled - Low NO _x burners/Flue gas recirculation	32	C	84	B
Tangential-Fired Boilers (All Sizes) [1-01-006-04]				
Uncontrolled	170	A	24	C
Controlled - Flue gas recirculation	76	D	98	D
Residential Furnaces (<0.3) [No SCC]				
Uncontrolled	94	B	40	B

^a Reference 13. Units are in pounds of pollutant per million standard cubic feet of natural gas fired. To convert from lb/10⁶ scf to kg/10⁶ m³, multiply by 16. Emission factors are based on an average natural gas higher heating value of 1,020 Btu/scf. To convert from lb/10⁶ scf to lb/MMBtu, divide by 1,020. The emission factors in this table may be converted to other natural gas heating values by multiplying the given emission factor by the ratio of the specified heating value to this average heating value. SCC = Source Classification Code. ND = no data. NA = not applicable.

^b Expressed as NO_x. For large and small wall fired boilers with SNCR control, apply a 24 percent reduction to the appropriate NO_x emission factor. For tangential-fired boilers with SNCR control, apply a 13 percent reduction to the appropriate NO_x emission factor.

^c NSPS = New Source Performance Standard as defined in 40 CFR 60 Subparts D and Db. Post-NSPS units are boilers with greater than 250 MMBtu/hr of heat input that commenced construction modification, or reconstruction after August 17, 1971, and units with heat input capacities between 100 and 250 MMBtu/hr that commenced construction modification, or reconstruction after June 19, 1984.

TABLE 1.4-2. EMISSION FACTORS FOR CRITERIA POLLUTANTS AND GREENHOUSE GASES FROM NATURAL GAS COMBUSTION^a

Pollutant	Emission Factor (lb/10 ⁶ scf)	Emission Factor Rating
CO ₂ ^b	120,000	A
Lead	0.0005	D
N ₂ O (Uncontrolled)	2.2	E
N ₂ O (Controlled-low-NO _x burner)	0.64	E
PM (Total) ^c	7.6	D
PM (Condensable) ^c	5.7	D
PM (Filterable) ^c	1.9	B
SO ₂ ^d	0.6	A
TOC	11	B
Methane	2.3	B
VOC	5.5	C

^a Reference 13. Units are in pounds of pollutant per million standard cubic feet of natural gas fired. Data are for all natural gas combustion sources. To convert from lb/10⁶ scf to kg/10⁶ m³, multiply by 16. To convert from lb/10⁶ scf to lb/MMBtu, divide by 1,020. The emission factors in this table may be converted to other natural gas heating values by multiplying the given emission factor by the ratio of the specified heating value to this average heating value. TOC = Total Organic Compounds. VOC = Volatile Organic Compounds.

^b Based on approximately 100% conversion of fuel carbon to CO₂. CO₂[lb/10⁶ scf] = (3.67) (CON) (C)(D), where CON = fractional conversion of fuel carbon to CO₂, C = carbon content of fuel by weight (0.76), and D = density of fuel, 4.2x10⁴ lb/10⁶ scf.

^c All PM (total, condensable, and filterable) is assumed to be less than 1.0 micrometer in diameter. Therefore, the PM emission factors presented here may be used to estimate PM₁₀, PM_{2.5} or PM₁ emissions. Total PM is the sum of the filterable PM and condensable PM. Condensable PM is the particulate matter collected using EPA Method 202 (or equivalent). Filterable PM is the particulate matter collected on, or prior to, the filter of an EPA Method 5 (or equivalent) sampling train.

^d Based on 100% conversion of fuel sulfur to SO₂. Assumes sulfur content is natural gas of 2,000 grains/10⁶ scf. The SO₂ emission factor in this table can be converted to other natural gas sulfur contents by multiplying the SO₂ emission factor by the ratio of the site-specific sulfur content (grains/10⁶ scf) to 2,000 grains/10⁶ scf.

Appendix E.4 Emission Inventory Supporting Information

Conoco Refinery

Post-It* Fax Note	7671	Date	1-22-01	# of pages	1
To	LONG NEWBY	From	JAY CHRISTOPHER		
Co./Dept.	APCD	Co.	CONOCO		
Phone #	303-692-9104	Phone #	303-286-59231		
Fax #	303-782-0278	Fax #	303-286-5866		

CONOCO DENVER REFINERY
 PM Data / Calculations Used For Title V PTE

APEN #	Source ID	PM-10 PTE provide in APCD	TV Fuel Use (mmscf/yr)	TV Factor (lb/mmscf)	Calc. PTE (lbs/year)	Calc. PTE (TPY)	Emission Factor Source
2 H-31	1.41	206.39	13.7	2827.543	1.41	AP-42, Section 1.4 (1/95 update)	
3 H-32	2.27	331.13	13.7	4536.481	2.27	AP-42, Section 1.4 (1/95 update)	
4 H-6	0.86	126.14	13.7	1728.118	0.86	AP-42, Section 1.4 (1/95 update)	
6 H-8	1.00	145.42	13.7	1992.254	1.00	AP-42, Section 1.4 (1/95 update)	
7 H-10	2.04	298.02	13.7	4082.874	2.04	AP-42, Section 1.4 (1/95 update)	
9 H-11	1.79	260.7	13.7	3571.59	1.79	AP-42, Section 1.4 (1/95 update)	
10 H-33	0.40	67.28	12	807.36	0.40	AP-42, Section 1.4 (1/95 update)	
11 H-12	1.77	258.77	13.7	3545.149	1.77	AP-42, Section 1.4 (1/95 update)	
12 H-37	3.43	501.42	13.7	6889.454	3.43	AP-42, Section 1.4 (1/95 update)	
13 H-17	3.50	511.58	13.7	7008.646	3.50	AP-42, Section 1.4 (1/95 update)	
14 H-13	0.36	59.57	12	714.84	0.36	AP-42, Section 1.4 (1/95 update)	
16 H-19	1.75	255.62	13.7	3501.994	1.75	AP-42, Section 1.4 (1/95 update)	
17 H-20	0.84	122.84	13.7	1680.168	0.84	AP-42, Section 1.4 (1/95 update)	
18 H-22	3.59	523.5	13.7	7171.95	3.59	AP-42, Section 1.4 (1/95 update)	
19 B-4	1.71	1138.8	3	3418.4	1.71	AP-42, Section 1.4 (1/95 update)	
21 B-6	1.46	972.36	3	2917.08	1.46	AP-42, Section 1.4 (1/95 update)	
23 B-8	2.12	1410.36	3	4231.08	2.12	AP-42, Section 1.4 (1/95 update)	
51 H-18	0.32	52.56	12	630.72	0.32	AP-42, Section 1.4 (1/95 update)	
52 H-16	0.32	52.56	12	630.72	0.32	AP-42, Section 1.4 (1/95 update)	
53 #1 SRU	0.01	0	0	0	0.00		
54 H-27	4.59	669.96	13.7	9178.452	4.59	AP-42, Section 1.4 (1/95 update)	
78 H-28,29,30	5.32	776.14	13.7	10633.12	5.32	AP-42, Section 1.4 (1/95 update)	

APEN #	Source ID	PM-10 PTE	TV Feed Rate (mBbl/yr)	TV Factor (lb/mBbl)	Calc. PTE (lbs/year)	Calc. PTE (TPY)
25 FCC	194.69	7300	50.8	370840	185.42	

Emission Factor Source
 PM emissions from the unit are controlled by a 2-stage cyclone. The emission factor is determined by applying an 85% control efficiency (see AP-42, Section 5.1, page 5.1-9) to the uncontrolled factors of 340 lbs/mBbl fresh feed.

APCD recall earlier discussion about using lower Feed Rate 185.42 is my number to use.

From: "Congram, Anthony R." <Anthony.R.Congram@usa.conoco.com>
To: 'MIKE Silverstein' <mcsilver@smtpgate.dphe.state.co.us>
Date: 3/26/01 2:15PM
Subject: RE: FCC Control Efficiency Question

FCC cyclones are completely integral. No means to bypass.

Tony Congram
Voice: 303-286-5890
Fax: 5866
anthony.r.congram@usa.conoco.com <mailto:anthony.r.congram@usa.conoco.com>

-----Original Message-----

From: MIKE Silverstein [SMTP:mcsilver@smtpgate.dphe.state.co.us]
Sent: Monday, March 26, 2001 2:05 PM
To: Anthony.R.Congram@usa.conoco.com
Subject: Re: FCC Control Efficiency Question

Next question: Are the cyclones inherent to the system - can they
be
by-passed/shut down and the FCCU still operated?

>>> "Congram, Anthony R." <Anthony.R.Congram@usa.conoco.com>
03/26/01

11:03AM >>>

Mike, is this enough of a reference (from AP-42, Chapter 5)?

Third paragraph under 5.1.2.2.2, page 8 or 9 of the document
(depending
on
formatting).

"FCC particulate emissions are controlled by cyclones and/or
electrostatic
precipitators.

Particulate control efficiencies are as high as 80 to 85 percent.^{3,5}

Carbon

monoxide waste heat boilers

reduce the CO and hydrocarbon emissions from FCC units to negligible
levels.³ TCC catalyst

regeneration produces similar pollutants to FCC units, but in much
smaller

quantities (Table 5.1-1).

The particulate emissions from a TCC unit are normally controlled by

high-efficiency cyclones.
Carbon monoxide and hydrocarbon emissions from a TCC unit are
incinerated to
negligible levels by
passing the flue gases through a process heater firebox or smoke
plume
burner. In some installations,
sulfur oxides are removed by passing the regenerator flue gases
through
a
water or caustic
scrubber.2-3,5"

If that's not what you need, please call me back. Thanks.

Tony Congram
Voice: 303-286-5890
Fax: 5866
anthony.r.congram@usa.conoco.com
<mailto:anthony.r.congram@usa.conoco.com>

CC: "Christopher, Jay S." <Jay.S.Christopher@usa.conoco.com>, "Walker,
Constance M. (Tance)" <Constance.M.Walker@usa.conoco.com>

From: "Christopher, Jay S." <Jay.S.Christopher@usa.conoco.com>
To: 'MIKE Silverstein' <mcsilver@smtgate.dphe.state.co.us>
Date: 3/27/01 3:26PM
Subject: RE: FCC Control Efficiency Question

Mike - sorry I have been difficult to get a hold of recently (traveling), and glad Tony Congram was able to provide some information for you. I thought it might be useful to package things together in one note, plus add some more detail. I am also copying Jerry Dilley since he has been involved in this discussion in the past.

Are the cyclones in the FCCU an inherent part of the process? Yes, they are. The cyclones are not a control device in the sense of an add-on control device, but are a standard part of the design and operation of the unit. In fact, if one looked at a petroleum refining text, cyclones would be included in the basic diagrams of a FCCU. The cyclones cannot be bypassed and the FCCU could not operate without the cyclones in place and functioning. Also, no one would have an incentive to operate without cyclones, as that would increase losses of expensive catalyst to the atmosphere, and I do not believe that a FCCU could achieve any reasonable opacity limit without the cyclones operating appropriately.

More background on the FCCU emission factor used by Conoco - As you know, the AP-42 emission factor (Table 5.1-1) is 242 pounds particulate per 1000 barrels of fresh feed to the unit. AP-42 also includes a range of 93 - 340 pounds. Conoco uses the upper end factor (i.e., the most conservative value) of 340, and then applies a control efficiency factor to that rate. As mentioned in the AP-42 text forwarded to you on 3/26/01 (paragraph following Section 5.1.2.2.2), AP-42 states "FCC particulate emissions are controlled by cyclones and/or electrostatic precipitators. Particulate control efficiencies are as high as 80 - 85%." Conoco has relied on that combination of factor and efficiency to estimate the particulate emissions from our FCCU.

A recent EPA publication reinforces Conoco's view that this control efficiency factor is reasonable. EPA's CHIEF website includes a program called the "Enhanced Particulate Matter Controlled Emissions Calculator," dated September 2000. This program is designed to determine control efficiencies for different particulate matter fractions. EPA lists three levels of cyclone efficiencies (high, medium, and low) in this database. Since coarser particulate fractions are controlled more effectively, the percentages shown for PM10 are conservative. EPA states that a medium efficiency cyclone is considered 85% effective for PM10 control. This, in our view, confirms the appropriateness of applying the 85% factor noted discussed in the initial paragraph.

Finally, we have also looked at our losses from a mass balance perspective. Conoco knows the average amount of catalyst that it adds to the unit, the average amount of spent catalyst that it sends offsite for reclamation, and the amount of catalyst that is suspended in the heavy oil bottoms from the unit (generally called slurry oil or clarified oil). The balance is unaccounted for losses that are assumed to be stack emissions. Using recent typical data, our mass data shows about 130 tons/year of these unaccounted for losses. In 2000, using the emission factor as above, we estimated about 165 tons/year of particulate emissions, providing further backup to our view that our numbers are conservative.

Therefore, Conoco feels that our use of the most conservative emission rate (340 instead of 242) and a reasonable efficiency factor (85%) results in a very reasonable derived emission factor of 51 pounds particulate per 1000 barrel feed.

I hope that this provides the information that you were looking for to resolve this issue. Thank you for your time in trying to get everyone on the same page.

Jay Christopher
Conoco Inc.
Air Program Leader - Denver
Rocky Mountain Business Unit
303-286-5731 (ETN 473)
303-286-5866 (fax)
jay.s.christopher@usa.conoco.com <jay.s.christopher@usa.conoco.com>

CC: "jdilley@raqc.org" <jdilley@raqc.org>

Public Service Company-Arapahoe Station

Table 5-2. Criteria Pollutant Emissions for the Arapahoe Combustion Turbine Project

Pollutant	Total Emissions From Both Turbines	
	lb/hr	tpy ^a
CO	290	90.8
NO _x	62	39.0
SO ₂	0.4	0.3
PM ₁₀	6	4.0
Pb	0	0

^aAnnual emissions based on an annual heat input of 883,854 MMBTU/year.

Notes:

- CO = carbon monoxide
- lb/hr = pounds per hour
- NO_x = nitrogen oxides
- Pb = lead
- PM₁₀ = fine particulate matter
- SO₂ = sulfur dioxide
- tpy = tons per year

Emissions exceed the CDPHE thresholds for dispersion modeling analysis for NO_x, and CO. Although the emissions for PM₁₀ are below the modeling threshold, a modeling analysis was conducted to verify that the turbines would not cause or contribute to any violation of a PM₁₀ NAAQS. Dispersion modeling analyses were conducted for these pollutants, and those analyses are described in detail in later sections of this report.

5.7 On-site PSD Increment Emission Inventory (Item #8 On APCD Review Checklist)

The Arapahoe Combustion Turbine Project is not a major modification, nor will it produce significant impacts of any criteria pollutant, as described in detail in later sections of this report. Therefore, an inventory of on-site increment consuming sources was not required.

Title V

Unit 1 Public Service Company of Colorado, Arapahoe Station Criteria and HAP Emissions							
Stack Identification Code: S001				Unit Code: B001			
Seasonal Fuel Usage (%)				Normal Operation of Unit			Space Heat (%)
Dec-Feb	Mar-May	Jun-Aug	Sep-Nov	Hours/Day	Days/Week	Hours/year	
25	26	25	24	24	7	8760	0
BOILER SPECIFICATIONS				STACK DATA			
Furnace Type: Top-fired wet bottom				Height (ft) 250			
Manufacturer: Babcock & Wilcox				Inside Diameter (ft) 15.75			
Model & Serial #: NB 16230				Exhaust Flow Rate (acfm)			
Unit Description: Top fired with ESP and SO3 gas conditioning				Normal 204,000 Max 240,000			
First Service or Last Mod. Date: 10/7/50				Velocity (fps) 17.5			
Max Continuous Rating (MMBtu/hr): 754.8 Coal				Calculated or Stack Test (C/ST) C			
748.5 Natural Gas				Exhaust Temperature (F) 265			
Maximum Hourly Fuel Usage (units/hr)				Exhaust Moisture Content (if modified) (%)			
Fuel Type Unit Rate				Normal 7 Max 9			
Bituminous Coal ton/hr 34				Orientation of Release Up			
Natural Gas Mcf/hr 750				Rainhat or Other Obstruction None			
Does the boiler/furnace have control technology (Y/N)? Y				Control Technology, %			
				ESP-SO3 conditioning 0 NOx 99.03 PM SOx 0			
Miscellaneous		Condensers		Adsorbers		Catalytic/Thermal Oxidation	
2000-400 NONE		2000-401 NONE		2000-402 NONE		2000-403 NONE	
Cyclones/Settling Chambers		Electrostatic Precipitators		Wet Collection Systems		Baghouses/Fabric Filters	
2000-404 NONE		2000-405 C001		2000-406 NONE		2000-407 NONE	
OPERATING PARAMETERS							
1994				Potential			
Coal (tons) = 136,821				Coal (tons) = 297,840			
Max Sulfur Content (%) = 0.50				Max Sulfur Content (%) = 1.00			
Max Ash Content (%) = 10.00				Max Ash Content (%) = 10.00			
HHV Coal (BTU/lb) = 11,100				HHV Coal (BTU/lb) = 11,100			
Natural Gas (Mcf) = 9,113				Natural Gas (Mcf) = 6,570,000			
Max Sulfur Content (%) = NA				Max Sulfur Content (%) = NA			
Max Ash Content (%) = NA				Max Ash Content (%) = NA			
HHV Gas (BTU/scf) = 998				HHV Gas (BTU/scf) = 998			
Operation Hours = 7,985				Operation Hours = 8,760			
EMISSION CALCULATIONS							
Pollutant	Source of Emission Factor	Units of Emission Factor	Emission Factors		Actual Emissions (ton/yr)	PTE 100% Coal (ton/yr)	PTE 100% Natural Gas (ton/yr)
			Coal	Natural Gas			
NOx	AP-42 ¹	lb/ton	21.7		1,487	3,232	
	AP-42 ²	lb/MMCF		550			1,807
CO	AP-42 ¹	lb/ton	0.50		34	74	
	AP-42 ²	lb/MMCF		40			131
NMTOC	AP-42 ¹	lb/ton	0.06		4	9	
	AP-42 ²	lb/MMCF		1.7			6
PM	AP-42 ¹	lb/ton	100.00		66	331	
	AP-42 ²	lb/MMCF		3.00			10
PM ₁₀	AP-42 ¹	% PM	67.00		44	222	
	AP-42 ²	lb/MMCF		3.00			10
SO ₂	AP-42 ¹	lb/ton	17.50		1,237	2,606	
	AP-42 ²	lb/MMCF		0.60			2
Antimony							
Arsenic							
Beryllium							
Cadmium							
Chromium							
Cobalt							
Lead	AP-42	lb/10 ¹² BTU	507	NA	0.007	0.037	NA
Manganese							
Mercury							
Nickel							
Selenium							
Thallium							
Formaldehyde							
POM							

Footnotes
 1. Section 1.1 Bituminous and Subbituminous Coal Combustion; Pulverized coal fired, dry bottom, wall fired
 2. Section 1.4 Natural Gas Combustion; Utility/large industrial boilers, uncontrolled
 3. Includes SO₂, conditioning emissions
 4. PM₁₀ is 67% of PM (Electrostatic precipitator controlled emissions, AP-42 Table 1.1-5)

Title II

Unit 2 Public Service Company of Colorado, Arapahoe Station Criteria and HAP Emissions							
Stack Identification Code : S001				Unit Code: B002			
Seasonal Fuel Usage (%)				Normal Operation of Unit			Space Heat (%)
Dec-Feb 28	Mar-May 30	Jun-Aug 27	Sep-Nov 15	Hours/Day 24	Days/Week 7	Hours/year 8760	0
BOILER SPECIFICATIONS				STACK DATA			
Furnace Type: Top-fired Wet Bottom				Height (ft) 250			
Manufacturer: Babcock & Wilcox				Inside Diameter (ft) 15.75			
Model & Serial #: NB 16231				Exhaust Flow Rate (acfm)			
Unit Description: Top fired with ESP and SO ₃ gas conditioning				Normal 204,000		Max 240,000	
First Service or Last Mod. Date: 3/1/51				Velocity (fps) 17.5			
Max Continuous Rating (MMBtu/hr) : 754.8 Coal				Calculated or Stack Test (C/ST) C			
748.5 Natural Gas				Exhaust Temperature (F) 265			
Maximum Hourly Fuel Usage (units/hr)				Exhaust Moisture Content (if modified) (%)			
Fuel Type		Unit	Rate	Normal 7		Max 9	
Bituminous Coal		ton/hr	34	Orientation of Release		Up	
Natural Gas		Mcf/hr	750	Rainhat or Other Obstruction		None	
Does the boiler/furnace have control technology (Y/N)? Y				Control Technology, %			
				Control NOx		PM SOx	
				ESP-SO ₃ conditioning 0		97.92 0	
Miscellaneous		Condensers		Adsorbers		Catalytic/Thermal Oxidation	
2000-400 NONE		2000-401 NONE		2000-402 NONE		2000-403 NONE	
Cyclones/Settling Chambers		Electrostatic Precipitators		Wet Collection Systems		Baghouses/Fabric Filters	
2000-404 NONE		2000-405 C002		2000-406 NONE		2000-407 NONE	
OPERATING PARAMETERS							
1994				Potential			
Coal (tons) = 148,645				Coal (tons) = 297,840			
Max Sulfur Content (%) = 0.50				Max Sulfur Content (%) = 1.00			
Max Ash Content (%) = 10.00				Max Ash Content (%) = 10.00			
HHV Coal (BTU/lb) = 11,100				HHV Coal (BTU/lb) = 11,100			
Natural Gas (Mcf) = 6,274				Natural Gas (Mcf) = 6,570,000			
Max Sulfur Content (%) = NA				Max Sulfur Content (%) = NA			
Max Ash Content (%) = NA				Max Ash Content (%) = NA			
HHV Gas (BTU/scf) = 998				HHV Gas (BTU/scf) = 998			
Operation Hours = 7,246				Operation Hours = 8,760			
EMISSION CALCULATIONS							
Pollutant	Source of Emission Factor	Units of Emission Factor	Emission Factors		Actual Emissions (ton/yr)	PTE 100% Coal (ton/yr)	PTE 100% Natural Gas (ton/yr)
			Coal	Natural Gas			
NOx	AP-42 ¹	lb/ton	21.7		1,615	3,232	
	AP-42 ²	lb/MMCF		550			1,807
CO	AP-42 ¹	lb/ton	0.50		37	74	
	AP-42 ²	lb/MMCF		40			131
NMTOC	AP-42 ¹	lb/ton	0.06		4	9	
	AP-42 ²	lb/MMCF		1.7			6
PM	AP-42 ¹	lb/ton	100.00		155	331	
PM ₁₀	AP-42 ¹	lb/MMCF		3.00			10
	AP-42 ²	% PM	67.00		104	222	
SO ₂	AP-42 ¹	lb/ton	17.50		1,341	2,606	
	AP-42 ²	lb/MMCF		0.60			2
Antimony							
Arsenic							
Beryllium							
Cadmium							
Chromium							
Cobalt							
Lead	AP-42	lb/10 ¹² BTU	507	NA	0.017	0.037	NA
Manganese							
Mercury							
Nickel							
Selenium							
Thallium							
Formaldehyde							
POM							

Footnotes

- Section 1.1 Bituminous and Subbituminous Coal Combustion; Pulverized coal fired, dry bottom, wall fired
- Section 1.4 Natural Gas Combustion; Utility/large industrial boilers, uncontrolled
- Includes SO₂ conditioning emissions
- PM₁₀ is 67% of PM (Electrostatic precipitator controlled emissions, AP-42 Table 1.1-5)

TITLE IV

Unit 3 Public Service Company of Colorado, Arapahoe Station Criteria and HAP Emissions							
Stack Identification Code : S002				Unit Code: B003			
Seasonal Fuel Usage (%)				Normal Operation of Unit			Space Heat (%)
Dec-Feb	Mar-May	Jun-Aug	Sep-Nov	Hours/Day	Days/Week	Hours/year	
25	28	24	23	24	7	8760	0
BOILER SPECIFICATIONS				STACK DATA			
Furnace Type: Top-fired				Height (ft) 250			
Manufacturer: Babcock & Wilcox				Inside Diameter (ft) 15.75			
Model & Serial #: NB 16911				Exhaust Flow Rate (acfm)			
Unit Description: Top Fired with fabric filter dust collectors (FFDC)				Normal 211,063		Max 255,067	
First Service or Last Mod. Date: 11/17/51				Velocity (fps) 18.1			
Max Continuous Rating (MMBtu/hr): 754.8 Coal				Calculated or Stack Test (C/ST) C			
748.5 Natural Gas				Exhaust Temperature (F) 268			
Maximum Hourly Fuel Usage (units/hr)				Exhaust Moisture Content (if modified) (%)			
Fuel Type		Unit	Rate	Normal 7		Max 9	
Bituminous Coal		ton/hr	34	Orientation of Release		Up	
Natural Gas		Mcf/hr	750	Rainhat or Other Obstruction			
				None			
Does the boiler/furnace have control technology (Y/N)? Y				Control Technology, %			
				Control	NOx	PM	SOx
				Baghouse	0	99.9	0
Miscellaneous		Condensers		Adsorbers		Catalytic/Thermal Oxidation	
2000-400 NONE		2000-401 NONE		2000-402 NONE		2000-403 NONE	
Cyclones/Settling Chambers		Electrostatic Precipitators		Wet Collection Systems		Baghouses/Fabric Filters	
2000-404 NONE		2000-405 NONE		2000-406 NONE		2000-407 C003	
OPERATING PARAMETERS							
1994				Potential			
Coal (tons) = 141,609				Coal (tons) = 297,840			
Max Sulfur Content (%) = 0.50				Max Sulfur Content (%) = 1.00			
Max Ash Content (%) = 10.00				Max Ash Content (%) = 10.00			
HHV Coal (BTU/lb) = 11,100				HHV Coal (BTU/lb) = 11,100			
Natural Gas (Mcf) = 4,742				Natural Gas (Mcf) = 6,570,000			
Max Sulfur Content (%) = NA				Max Sulfur Content (%) = NA			
Max Ash Content (%) = NA				Max Ash Content (%) = NA			
HHV Gas (BTU/scf) = 998				HHV Gas (BTU/scf) = 998			
Operation Hours = 7,925				Operation Hours = 8,760			
EMISSION CALCULATIONS							
Pollutant	Source of Emission Factor	Units of Emission Factor	Emission Factors		Actual Emissions (ton/yr)	PTE 100% Coal (ton/yr)	PTE 100% Natural Gas (ton/yr)
			Coal	Natural Gas			
NOx	AP-42 ¹	lb/ton	21.7		1,538	3,232	
	AP-42 ²	lb/MMCF		550			1,807
CO	AP-42 ¹	lb/ton	0.50		35	74	
	AP-42 ²	lb/MMCF		40			131
NMTOC	AP-42 ¹	lb/ton	0.06		4	9	
	AP-42 ²	lb/MMCF		1.7			6
PM	AP-42 ¹	lb/ton	100.00		7	331	
	AP-42 ²	lb/MMCF		3.00			10
PM ₁₀	AP-42 ¹	% PM	92.00		7	304	
	AP-42 ²	lb/MMCF		3.00			10
SOx	AP-42 ¹	lb/ton	17.50		1,239	2,606	
	AP-42 ²	lb/MMCF		0.60			2
Antimony							
Arsenic							
Beryllium							
Cadmium							
Chromium							
Cobalt							
Lead	AP-42	lb/10 ⁶ 12 BTU	507	NA	0.001	0.037	NA
Manganese							
Mercury							
Nickel							
Selenium							
Thallium							
Formaldehyde							
POM							

Footnotes

- Section 1.1 Bituminous and Subbituminous Coal Combustion; Pulverized coal fired, dry bottom, wall fired
- Section 1.4 Natural Gas Combustion; Utility/large industrial boilers, uncontrolled
- PM₁₀ is 92% of PM (Baghouse controlled emissions, AP-42 Table 1.1-5)

92.97%

3.0%

20.9%

Title ✓

Unit 4 Public Service Company of Colorado, Arapahoe Station Criteria and HAP Emissions							
Stack Identification Code: S002				Unit Code: B004			
Seasonal Fuel Usage (%)				Normal Operation of Unit			Space Heat (%)
Dec-Feb	Mar-May	Jun-Aug	Sep-Nov	Hours/Day	Days/Week	Hours/year	
25	26	25	24	24	7	8760	0
BOILER SPECIFICATIONS				STACK DATA			
Furnace Type: Top-fired wet bottom with under fire air				Height (ft) 250			
Manufacturer: Babcock & Wilcox				Inside Diameter (ft) 15.75			
Model & Serial #: HSB 18469				Exhaust Flow Rate (acfm)			
Unit Description: Low NOx burner, overfire air, FFDC, DSI				Normal 384,033		Max 469,812	
First Service or Last Mod. Date: 8/22/55				Velocity (fps) 32.9			
Max Continuous Rating (MMBtu/hr): 1709.4 Coal				Calculated or Stack Test (C/ST) C			
1706.58 Natural Gas				Exhaust Temperature (F) 270			
Maximum Hourly Fuel Usage (units/hr)				Exhaust Moisture Content (if modified) (%)			
Fuel Type	Unit	Rate		Normal 7		Max 9	
Bituminous Coal	ton/hr	77		Orientation of Release		Up	
Natural Gas	Mcf/hr	1710		Rainhat or Other Obstruction		None	
Does the boiler/furnace have control technology (Y/N)? Y				Control Technology, %			
				Control NOx		PM	
				Baghouse, Low NOx, & DSI 60.3		99.9	
				SOx		20	
Miscellaneous		Condensers		Adsorbers		Catalytic/Thermal Oxidation	
2000-400	C004, C005	2000-401	NONE	2000-402	NONE	2000-403	NONE
Cyclones/Settling Chambers		Electrostatic Precipitators		Wet Collection Systems		Baghouses/Fabric Filters	
2000-404	NONE	2000-405	NONE	2000-406	NONE	2000-407	C006
OPERATING PARAMETERS							
1994				Potential			
Coal (tons) =		323,480		Coal (tons) =		674,520	
Max Sulfur Content (%) =		0.50		Max Sulfur Content (%) =		1.00	
Max Ash Content (%) =		10.00		Max Ash Content (%) =		10.00	
HHV Coal (BTU/lb) =		11,100		HHV Coal (BTU/lb) =		11,100	
Natural Gas (Mcf) =		34,237		Natural Gas (Mcf) =		14,979,600	
Max Sulfur Content (%) =		NA		Max Sulfur Content (%) =		NA	
Max Ash Content (%) =		NA		Max Ash Content (%) =		NA	
HHV Gas (BTU/scf) =		998		HHV Gas (BTU/scf) =		998	
Operation Hours =		8,490		Operation Hours =		8,760	
EMISSION CALCULATIONS							
Pollutant	Source of Emission Factor	Units of Emission Factor	Emission Factors		Actual Emissions (ton/yr)	PTE 100% Coal (ton/yr)	PTE 100% Natural Gas (ton/yr)
			Coal	Natural Gas			
NOx	AP-42 ¹	lb/ton	21.7		1,397	4,492	4,489
	AP-42 ²	lb/MMCF		550			
CO	AP-42 ¹	lb/ton	0.50		82	169	
	AP-42 ²	lb/MMCF		40			234
NMTOC	AP-42 ¹	lb/ton	0.06		10	20	
	AP-42 ²	lb/MMCF		1.7			16
PM	AP-42 ¹	lb/ton	100.00		16	749	
	AP-42 ²	lb/MMCF		3.00			748
PM ₁₀	AP-42 ¹	% PM	92.00		15	689	22
	AP-42 ²	lb/MMCF		3.00			
SO ₂	AP-42 ¹	lb/ton	17.50		2,264	6,589	
	AP-42 ²	lb/MMCF		0.60			2,953
Antimony							
Arsenic							
Beryllium							
Cadmium							
Chromium							
Cobalt							
Lead	AP-42	lb/10 ¹² BTU	507	NA	0.002	0.084	NA
Manganese							
Mercury							
Nickel							
Selenium							
Thallium							
Formaldehyde							
POM							

Footnotes

- Section 1.1 Bituminous and Subbituminous Coal Combustion; Pulverized coal fired, dry bottom, tangentially fired
- Section 1.4 Natural Gas Combustion; Utility/large industrial boilers, Controlled - Low NOx burners
- PM₁₀ is 92% of PM (Baghouse controlled emissions, AP-42 Table 1.1-5)

189.286

189.544

Public Service Company-Cherokee Station

Title V

Unit 1 Public Service Company of Colorado, Cherokee Station Criteria and HAP Emissions							
Stack Identification Code: S001				Emission Unit Code: B001			
Seasonal Fuel Usage (%)				Normal Operation of Unit			Space Heat (%)
Dec-Feb	Mar-May	Jun-Aug	Sep-Nov	Hours/Day	Days/Week	Hours/year	
28	25	27	20	24	7	8,760	0
BOILER SPECIFICATIONS				STACK DATA (S001)			
Furnace Type: Top Fired				Height (ft): 300			
Manufacturer: Babcock & Wilcox				Inside Diameter (ft): 16			
Model & Serial #: RB 251 NY-771302				Exhaust Flow Rate (acfm): Normal 789,395 Max 937,595			
Unit Description: N/A				Velocity (fps): 65.5			
First Service or Last Mod. Date: Aug. 12, 1957				Calculated or Stack Test (C/ST): ST			
Max Continuous Rating (mmBTU/hr): 1,392 Coal 1,259 Natural Gas				Exhaust Temperature (F): 265			
Maximum Hourly Fuel Usage (units/hr)				Exhaust Moisture Content (if modified) (%): Normal 6 Max 10			
Fuel Type	Unit	Rate		Orientation of Release: Up			
Bituminous Coal	ton/hr	61.8		Rainhat or Other Obstruction: None			
Natural Gas	mc/hr	1,240					
Does the boiler/furnace have control technology (Y/N): Y				Control Technology, %			
				Control	NOx	PM	SOx
				Baghouse	0	99.9	0
Miscellaneous		Condensers		Adsorbers		Catalytic/Thermal Oxidation	
2000-400	NONE	2000-401	NONE	2000-402	NONE	2000-403	NONE
Cyclones/Settling Chambers		Electrostatic Precipitators		Wet Collection Systems		Baghouses/Fabric Filters	
2000-404	NONE	2000-405	NONE	2000-406	NONE	2000-407	C001
OPERATING PARAMETERS							
1994				Potential			
Coal (ton) =		371,282		Coal (ton) =		541,368	
Avg. Sulfur Content (%) =		0.39		Avg. Sulfur Content (%) =		1.00	
Avg. Ash Content (%) =		9.95		Avg. Ash Content (%) =		9.95	
HHV Coal (BTU/lb) =		11,262		HHV Coal (BTU/lb) =		11,262	
Natural Gas (mcf) =		152,312		Natural Gas (mcf) =		10,862,400	
Avg. Sulfur Content (%) =		N/A		Avg. Sulfur Content (%) =		N/A	
Avg. Ash Content (%) =		N/A		Avg. Ash Content (%) =		N/A	
HHV Gas (BTU/scf) =		1,015		HHV Gas (BTU/scf) =		1,015	
Operation Hours =		7,771		Operation Hours =		8,760	
EMISSION CALCULATIONS							
Pollutant	Source of Emission Factor	Units of Emission Factor	Emission Factors		Actual Emissions (ton/yr)	PTE 100% Coal (ton/yr)	PTE 100% Natural Gas (ton/yr)
			Coal	Natural Gas			
NOx	AP-42(1)	lb/ton	21.7		4,070	5,874	2,987
	AP-42(2)	lb/mmCF		550	48		
CO	AP-42(1)	lb/ton	0.50		96	135	217
	AP-42(2)	lb/mmCF		40	92		
NMTOC	AP-42(1)	lb/ton	0.06		11	16	9.2
	AP-42(2)	lb/mmCF		1.7			16
PM	AP-42(1)	lb/ton	99.50		18	610	551
	AP-42(2)	lb/mmCF	18A	3			16
PM ₁₀	AP-42(3)	% PM	92.00		17	561	
	AP-42(2)	lb/mmCF		3			16
SOx	AP-42(1)	lb/ton	13.65		2,534	6,707	6065
	AP-42(2)	lb/mmCF	385 = 148	0.60	4751		3.3
Antimony							
Arsenic							
Beryllium							
Cadmium							
Chromium							
Cobalt							
Lead	AP-42	lb/10 ¹² BTU	507	NA	0.015	0.49	NA
Manganese					2.11	3	
Mercury							
Nickel							
Selenium							
Thallium							
Formaldehyde							
POM							

Footnotes
 1. Section 1.1 Bituminous and Subbituminous Coal Combustion; Pulverized coal fired, dry bottom, wall fired
 2. Section 1.4 Natural Gas Combustion; Utility/large industrial boilers, uncontrolled
 3. PM10 is 92% of PM (baghouse controlled emissions, AP-42 Table 1.1-5)

What is control factor for Pb?
 99.390

1392 mcf/yr
 0.011262 mcf/yr x 1392 = 15.68
 15.68 / 16 = 0.98

Title IV

Unit 2 Public Service Company of Colorado, Cherokee Station Criteria and HAP Emissions							
Stack Identification Code : S001				Emission Unit Code: B002			
Seasonal Fuel Usage (%)				Normal Operation of Unit			Space Heat (%)
Dec-Feb	Mar-May	Jun-Aug	Sep-Nov	Hours/Day	Days/Week	Hours/year	
31	33	11	25	24	7	8,760	0
BOILER SPECIFICATIONS				STACK DATA (S001)			
Furnace Type: Top Fired				Height (ft) 300			
Manufacturer: Babcock & Wilcox				Inside Diameter (ft) 16			
Model & Serial #: RB 295 NY-771602				Exhaust Flow Rate (acfm)			
Unit Description: N/A				Normal 789,395 Max 937,595			
First Service or Last Mod. Date: May. 19, 1959				Velocity (fps) 65.5			
Max Continuous Rating (mmBTU/hr) : 1,392 Coal				Calculated or Stack Test (C/ST) ST			
1,259 Natural Gas				Exhaust Temperature (F) 265			
Maximum Hourly Fuel Usage (units/hr)				Exhaust Moisture Content (if modified) (%)			
Fuel Type	Unit	Rate		Normal 6 Max 10			
Bituminous Coal	ton/hr	61.8		Orientation of Release Up			
Natural Gas	mcf/hr	1,240		Rainhat or Other Obstruction None			
Does the boiler/furnace have control technology (Y/N) Y				Control Technology, %			
				NOx 0 PM 99.9 SOx 0			
Miscellaneous				Control Technology, %			
2000-400 Condensers				2000-402 Adsorbers 2000-403 Catalytic/Thermal Oxidation			
2000-404 Cyclones/Settling Chambers				2000-406 Wet Collection Systems 2000-407 Baghouses/Fabric Filters			
2000-405 Electrostatic Precipitators				2000-407 C002			
OPERATING PARAMETERS							
1994				Potential			
Coal (ton) = 261,335				Coal (ton) = 541,268			
Avg. Sulfur Content (%) = 0.39				Avg. Sulfur Content (%) = 1.00			
Avg. Ash Content (%) = 9.95				Avg. Ash Content (%) = 9.95			
HHV Coal (BTU/lb) = 11,262				HHV Coal (BTU/lb) = 11,262			
Natural Gas (mcf) = 311,320				Natural Gas (mcf) = 10,862,400			
Avg. Sulfur Content (%) = N/A				Avg. Sulfur Content (%) = N/A			
Avg. Ash Content (%) = N/A				Avg. Ash Content (%) = N/A			
HHV Gas (BTU/scf) = 1,015				HHV Gas (BTU/scf) = 1,015			
Operation Hours = 6,669				Operation Hours = 8,760			
EMISSION CALCULATIONS							
Pollutant	Source of Emission Factor	Units of Emission Factor	Emission Factors		Actual Emissions (ton/yr)	PTE 100% Coal (ton/yr)	PTE 100% Natural Gas (ton/yr)
			Coal	Natural Gas			
NOx	AP-42(1)	lb/ton	21.7		2,921	5,874	
	AP-42(2)	lb/mmCF		550	2835		2,987
CO	AP-42(1)	lb/ton	0.50		72	135	
	AP-42(2)	lb/mmCF		40	16		217
NMTOC	AP-42(1)	lb/ton	0.06		8.1	16	
	AP-42(2)	lb/mmCF		1.7	78		9.2
PM	AP-42(1)	lb/ton	99.50		13	610	
	AP-42(2)	lb/mmCF	10A	3			551
PM ₁₀	AP-42(3)	% PM	92.00		12	561	
	AP-42(2)	lb/mmCF		3			551
SOx	AP-42(1)	lb/ton	13.65		1,784	6,707	
	AP-42(2)	lb/mmCF	365-1482	0.60	1936		6065
Antimony							
Arsenic							
Beryllium							
Cadmium							
Chromium							
Cobalt							
Lead	AP-42	lb/10 ¹² BTU	507	NA	0.010	0.49	NA
Manganese						3	
Mercury							
Nickel							
Selenium							
Thallium							
Formaldehyde							
POM							

PTE same as for Unit 1

Footnotes
 1. Section 1.1 Bituminous and Subbituminous Coal Combustion; Pulverized coal fired, dry bottom, wall fired
 2. Section 1.4 Natural Gas Combustion; Utility/large industrial boilers, uncontrolled
 3. PM10 is 92% of PM (baghouse controlled emissions, AP-42 Table 1.1-5)

Title V

Unit 3 Public Service Company of Colorado, Cherokee Station Criteria and HAP Emissions							
Stack Identification Code: S002			Emission Unit Code: B003				
Seasonal Fuel Usage (%)			Normal Operation of Unit			Space Heat (%)	
Dec-Feb	Mar-May	Jun-Aug	Sep-Nov	Hours/Day	Days/Week	Hours/year	
25	27	29	19	24	7	8,760	
0							
BOILER SPECIFICATIONS			STACK DATA (S002)				
Furnace Type: Front Fired			Height (ft): 300				
Manufacturer: Babcock & Wilcox			Inside Diameter (ft): 19.5				
Model & Serial #: RB 344 NY-771802			Exhaust Flow Rate (acfm)				
Unit Description: Low NOx burner, with overfire air			Normal: 495,419 Max: 745,517				
First Service or Last Mod. Date: Apr. 28, 1962			Velocity (fps): 27.7				
Max Continuous Rating (mmBTU/hr): 1,877 Coal			Calculated or Stack Test (C/ST): ST				
1,697 Natural Gas			Exhaust Temperature (F): 267				
Maximum Hourly Fuel Usage (units/hr)			Exhaust Moisture Content (if modified) (%)				
Fuel Type	Unit	Rate	Normal: 6 Max: 10				
Bituminous Coal	ton/hr	83.3	Orientation of Release: Up				
Natural Gas	mcf/hr	1,673	Rainhat or Other Obstruction: None				
Does the boiler/furnace have control technology (Y/N) Y Control Technology, %							
			Control	NOx	PM	SOx	
			Baghouse & Low NOx	53.5	99.9	0	
Miscellaneous		Condensers	Adsorbers	Catalytic/Thermal Oxidation			
2000-400	C005	2000-401	NONE	2000-402	NONE	2000-403	
Cyclones/Settling Chambers		Electrostatic Precipitators	Wet Collection Systems		Baghouses/Fabric Filters		
2000-404	NONE	2000-405	NONE	2000-406	NONE	2000-407	
				C003			
OPERATING PARAMETERS							
1994			Potential				
Coal (ton) = 425,597			Coal (ton) = 729,708				
Avg. Sulfur Content (%) = 0.39			Avg. Sulfur Content (%) = 1.00				
Avg. Ash Content (%) = 9.95			Avg. Ash Content (%) = 9.95				
HHV Coal (BTU/lb) = 11,262			HHV Coal (BTU/lb) = 11,262				
Natural Gas (mcf) = 479,215			Natural Gas (mcf) = 14,655,480				
Avg. Sulfur Content (%) = N/A			Avg. Sulfur Content (%) = N/A				
Avg. Ash Content (%) = N/A			Avg. Ash Content (%) = N/A				
HHV Gas (BTU/scf) = 1,015			HHV Gas (BTU/scf) = 1,015				
Operation Hours = 7,576			Operation Hours = 8,760				
EMISSION CALCULATIONS							
Pollutant	Source of Emission Factor	Units of Emission Factor	Emission Factors		Actual Emissions (ton/yr)	PTE 100% Coal (ton/yr)	PTE 100% Natural Gas (ton/yr)
			Coal	Natural Gas			
NOx	AP-42(1)	lb/ton	21.7		2,279	4,931	4,400
	AP-42(2)	lb/mmCF		550	2,147		4,030
CO	AP-42(1)	lb/ton	0.50		116	182	293
	AP-42(2)	lb/mmCF		40	106		
NMTOC	AP-42(1)	lb/ton	0.06		13	22	12
	AP-42(2)	lb/mmCF		1.7			
PM	AP-42(1)	lb/ton	99.50		21	822	743
	AP-42(2)	lb/mmCF	100	3			22
PM10	AP-42(3)	% PM	92.00		19	756	743
	AP-42(2)	lb/mmCF		3			22
SOx	AP-42(1)	lb/ton	13.65		2,905	9,040	8,176
	AP-42(2)	lb/mmCF	285-14.89	0.60	216		4.4
Antimony							
Arsenic							
Beryllium							
Cadmium							
Chromium							
Cobalt							
Lead	AP-42	lb/10 ¹² BTU	507	NA	0.017	0.66	NA
Manganese						1.2	
Mercury							
Nickel							
Selenium							
Thallium							
Formaldehyde							
POM							

Footnotes
 1. Section 1.1 Bituminous and Subbituminous Coal Combustion; Pulverized coal fired, dry bottom, wall fired
 2. Section 1.4 Natural Gas Combustion; Utility/large industrial boilers, uncontrolled
 3. PM10 is 92% of PM (baghouse controlled emissions, AP-42 Table 1.1-5)

low NOx burner
 53.5% control eff.

Title V

Unit 4 Public Service Company of Colorado, Cherokee Station Criteria and HAP Emissions							
Stack Identification Code: S003				Emission Unit Code: B004			
Seasonal Fuel Usage (%)				Normal Operation of Unit			Space Heat (%)
Dec-Feb	Mar-May	Jun-Aug	Sep-Nov	Hours/Day	Days/Week	Hours/year	
25	24	27	24	24	7	8,760	0
BOILER SPECIFICATIONS				STACK DATA (S003)			
Furnace Type: Corner tilting tangential firing				Height (ft): 400			
Manufacturer: Combustion Engineering				Inside Diameter (ft): 22			
Model & Serial #: 12465 C400016				Exhaust Flow Rate (acfm)			
Unit Description: Low NOx burner, with overfire air				Normal: 1,041,916 Max: 1,389,927			
First Service or Last Mod. Date: Nov. 20, 1968				Velocity (fps): 45.7			
Max Continuous Rating (mmBTU/hr): 3,520 Coal				Calculated or Stack Test (C/ST): C			
Natural Gas				Exhaust Temperature (F): 267			
Maximum Hourly Fuel Usage (units/hr)				Exhaust Moisture Content (if modified) (%)			
Fuel Type				Normal: 6 Max: 10			
Bituminous Coal				Orientation of Release: Up			
Natural Gas				Rainhat or Other Obstruction: None			
Does the boiler/furnace have control technology (Y/N): Y				Control Technology: %			
				Control: NOx 62 PM 99.9 SOx 37.5			
				Baghouse, Low NOx, & DSI			
Miscellaneous				Adsorbers			
C006, C007				2000-402 NONE			
Condensers				Catalytic/Thermal Oxidation			
2000-401 NONE				2000-403 NONE			
Cyclones/Settling Chambers				Wet Collection Systems			
2000-404 NONE				2000-406 NONE			
Electrostatic Precipitators				Baghouses/Fabric Filters			
2000-405 NONE				2000-407 C004			
OPERATING PARAMETERS							
1994				Potential			
Coal (ton) = 981,255				Coal (ton) = 1,369,188			
Avg. Sulfur Content (%) = 0.39				Avg. Sulfur Content (%) = 1.00			
Avg. Ash Content (%) = 9.95				Avg. Ash Content (%) = 9.95			
HHV Coal (BTU/lb) = 11,262				HHV Coal (BTU/lb) = 11,262			
Natural Gas (mcf) = 333,192				Natural Gas (mcf) = 15,321,240			
Avg. Sulfur Content (%) = N/A				Avg. Sulfur Content (%) = N/A			
Avg. Ash Content (%) = N/A				Avg. Ash Content (%) = N/A			
HHV Gas (BTU/scf) = 1,015				HHV Gas (BTU/scf) = 1,015			
Operation Hours = 8,102				Operation Hours = 8,760			
EMISSION CALCULATIONS							
Pollutant	Source of Emission Factor	Units of Emission Factor	Emission Factors		Actual Emissions (ton/yr)	PTE 100% Coal (ton/yr)	PTE 50% Coal/50% Gas (ton/yr)
			Coal	Natural Gas			
NOx	AP-42(1)	lb/ton	14.4	550	216	6,939	6,969
	AP-42(2)	lb/mmCF			2,684		
CO	AP-42(1)	lb/ton	0.50	40	252	342	478
	AP-42(2)	lb/mmCF			246		
NMTOC	AP-42(1)	lb/ton	0.06	1.7	30	41	34
	AP-42(2)	lb/mmCF					
PM	AP-42(1)	lb/ton	99.50	3	49	1,542	794
	AP-42(2)	lb/mmCF	10A				
PM ₁₀	AP-42(3)	% PM	92.00	3	45	1,419	732
	AP-42(2)	lb/mmCF					
SOx	AP-42(1)	lb/ton	13.65	0.60	4,188	16,962	8,485
	AP-42(2)	lb/mmCF	385-14.89		4965		
Antimony							
Arsenic							
Beryllium							
Cadmium							
Chromium							
Cobalt							
Lead	AP-42	lb/10 ¹² BTU	507	NA	0.039	±2	0.62
Manganese						7.8	
Mercury							
Nickel							
Selenium							
Thallium							
Formaldehyde							
POM							

Footnotes
 1. Section 1.1 Bituminous and Subbituminous Coal Combustion; Pulverized coal fired, dry bottom, tangentially fired
 2. Section 1.4 Natural Gas Combustion; Utility/large industrial boilers, uncontrolled
 3. PM10 is 92% of PM (baghouse controlled emissions, AP-42 Table 1.1-5)

30,379,680

PTE
 100% 920 690
 6,939
 607
 26
 1342
 1542
 16962

50% control device 37.5-920 off

625

low NOx burner 62% control off

Public Service Company-Valmont Station

TABLE 3-1

Valmont Combustion Turbine Project Emissions Summary ^a

Pollutant	Significant Emission Rates (tpy)	Annual Emissions (tpy), Total of Both Turbines plus Unit #8 Air Preheater ^b	Maximum Hourly Emissions (lb/hr), Each of Two Turbines ^c	Maximum Hourly Emissions (lb/hr), Unit #8 Air Preheater
Carbon Monoxide	100	90.8	220	0.24
Nitrogen Oxides	40	39.1	31	0.24
Sulfur Dioxide ^d	40	0.3	0.2	0.01
Particulate Matter ^e	25	4.0	3	0.04
Fine Particulate Matter PM ₁₀ ^e	15	4.0	3	0.04
Ozone	40 (voc)	1.5	5.1	0.04
Lead	0.6	Not Emitted	Not Emitted	Not Emitted
Fluorides	3	Not Emitted	Not Emitted	Not Emitted
Sulfuric Acid Mist	7	Not Emitted	Not Emitted	Not Emitted
Total Reduced Sulfur	10	Not Emitted	Not Emitted	Not Emitted
Reduced Sulfur Compounds	10	Not Emitted	Not Emitted	Not Emitted
Formaldehyde	Not Applicable	0.3	0.2	0.0005
Total HAPs	Not Applicable	0.6	0.4	0.01

^aDetailed emission calculations are provided in Appendix A.

^bAnnual emissions are based on total heat inputs for the Unit #7 turbine of 442,000 MMBtu per year, for the Unit #8 turbine of 442,000 MMBtu/year, and the Unit #8 air preheater of 6,700 MMBtu/year.

^cHourly emissions are based on operating conditions that result in maximum emissions for each pollutant. For sulfur dioxide, particulate matter, and fine particulate matter, these conditions are: operation at full load across all ambient temperatures. For carbon monoxide, oxides of nitrogen, and volatile organic compounds, maximum emitting conditions are: 100 percent load at 25 degrees Fahrenheit.

^dThe SO₂ emissions were estimated from the EPA default emissions rate of 0.0006 pounds SO₂ per MMBtu, for combustion turbine burning pipeline quality natural gas as obtained from 40 CFR 75, Appendix D, 2.3.2.

^eThe PM and PM₁₀ emissions are the sum of solid and condensable fractions.

Notes:

tpy = tons per year

lb/hr = pounds per hour

Public Service Company-Zuni Station

**Unit 1A
Public Service Company of Colorado, Zuni Station
Criteria and HAP Emissions**

Stack Identification Code: S001				Unit Code: B001				
Seasonal Fuel Usage (%)				Normal Operation of Unit			Space Heat (%)	
Dec-Feb	Mar-May	Jun-Aug	Sep-Nov	Hours/Day	Days/Week	Hours/year		
41	16	20	23	24	7	8760	0	
BOILER SPECIFICATIONS				STACK DATA				
Furnace Type: Front-fired				Height (ft)				280
Manufacturer: Babcock & Wilcox				Inside Diameter (ft)				13
Model & Serial #: 15253				Exhaust Flow Rate (ACFM)				
Unit Description: N/A				Normal				120,000
First Service or Last Mod. Date: 1948				Max				240,000
Max Continuous Rating (MMBTU/hr): 450 Natural Gas				Exhaust Velocity (fps)				15.08
450 #6 Fuel Oil				Calculated or Stack Test (C/ST)				ST
Maximum Hourly Fuel Usage (units/hr)				Exhaust Temperature (F)				500
Fuel Type				Exhaust Moisture Content (if modified) (%)				
Natural Gas				Normal				10
Unit				Max				16
Rate				Orientation of Release				Up
Mc/hr				Rainhat or Other Obstruction				None
#6 Fuel Oil								
gal/hr								
3,061								
Does the boiler/furnace have control technology (Y/N)				Control Technology, %				
N				Control				NOx
				None				0
				PM				0
				SOx				0
Miscellaneous				2000-401				Condensers
NONE				NONE				Adsorbers
								Catalytic/Thermal Oxidation
								2000-402
								NONE
Cyclones/Settling Chambers				2000-403				Wet Collection Systems
NONE				NONE				2000-404
								Baghouses/Fabric Filters
								2000-405
								NONE
								2000-406
								2000-407
								NONE
OPERATING PARAMETERS								
1994				Potential				
Natural Gas (Mcf) =				Natural Gas (Mcf) =				
508,496				3,942,000				
Max Sulfur Content (%) =				Max Sulfur Content (%) =				
0.01				0.01				
Max Ash Content (%) =				Max Ash Content (%) =				
0.00				0.00				
HHV Gas (BTU/cf) =				HHV Gas (BTU/cf) =				
1,000				1,000				
#6 Fuel Oil (gal) =				#6 Fuel Oil (gal) =				
2,650				26,816,327				
Max Sulfur Content (%) =				Max Sulfur Content (%) =				
0.79				0.79				
Max Ash Content (%) =				Max Ash Content (%) =				
0.1				0.1				
HHV Fuel Oil (MBTU/gal) =				HHV Fuel Oil (MBTU/gal) =				
147				147				
Operation Hours =				Operation Hours =				
3,459				8,760				
EMISSION CALCULATIONS								
Pollutant	Source of Emission Factor	Units of Emission Factor	Emission Factors		Actual Emissions (ton/yr)	PTE 100% Natural Gas (ton/yr)	PTE 100% #6 Fuel Oil (ton/yr)	
			Natural Gas	#6 Fuel Oil				
NOx	AP-42(1)	lb/MMCF	550		140			
	AP-42(4)	lb/10 ³ gal		67		1,084	898	
CO	AP-42(1)	lb/MMCF	40		10.2	79		
	AP-42(4)	lb/10 ³ gal		5			67	
NMTOC	AP-42(3)	lb/MMCF	1.7		0.43	3.4		
	AP-42(5)	lb/10 ³ gal		0.76			10	
PM	AP-42(2)	lb/MMCF	3.0		0.78	5.9		
	AP-42(4)	lb/10 ³ gal		10.48			141	
PM ₁₀	AP-42(2)	lb/MMCF	3.0		0.55	5.9		
	AP-42(6)	% PM		71			100	
SOx	AP-42(1)	lb/MMCF	0.6		0.32	1.2		
	AP-42(4)	lb/10 ³ gal		129			1,577	
Antimony								
Arsenic								
Beryllium								
Cadmium								
Chromium								
Cobalt								
Lead	AP-42	lb/10 ¹² BTU	NA	111	0.0000	NA	0.22	
Manganese								
Mercury								
Nickel								
Selenium								
Thallium								
Formaldehyde								
POM								

Footnotes

- Section 1.4, Natural Gas Combustion, Table 1.4-2.
- Section 1.4, Natural Gas Combustion, Table 1.4-1.
- Section 1.4, Natural Gas Combustion, Table 1.4-3.
- Section 1.3 Fuel Oil Combustion, Table 1.3-2.
- Section 1.3, Fuel Oil Combustion, Table 1.3-4.
- PM₁₀ is 71% of PM (uncontrolled PM emissions AP-42, Table 1.3-5)

Unit 1B Public Service Company of Colorado, Zuni Station Criteria and HAP Emissions							
Stack Identification Code: S002				Unit Code: B002			
Seasonal Fuel Usage (%)				Normal Operation of Unit			Space Heat (%)
Dec-Feb	Mar-May	Jun-Aug	Sep-Nov	Hours/Day	Days/Week	Hours/year	
41	16	20	23	24	7	8760	0
BOILER SPECIFICATIONS				STACK DATA			
Furnace Type: Front fired				Height (ft) 107			
Manufacturer: Babcock & Wilcox				Inside Diameter (ft) 6			
Model & Serial #: 15265				Exhaust Flow Rate (acfm)			
Unit Description: N/A				Normal 120,000 Max 204,000			
First Service or Last Mod. Date: 1948				Exhaust Velocity (fps) 70.77			
Max Continuous Rating (MMBtu/hr): 200 Natural Gas				Calculated or Stack Test (C/ST) ST			
200 #6 Fuel Oil				Exhaust Temperature (F) 500			
Maximum Hourly Fuel Usage (units/hr)				Exhaust Moisture Content (if modified) (%)			
Fuel Type Unit Rate				Normal 10 Max 16			
Natural Gas mcf/hr 200				Orientation of Release Up			
#6 Fuel Oil gal/hr 1,361				Rainhat or Other Obstruction None			
Does the boiler/furnace have control technology (Y/N) N				Control Technology, %			
				Control NOx PM SOx			
				None 0 0 0			
Miscellaneous		Condensers		Adsorbers		Catalytic/Thermal Oxidation	
2000-400 NONE		2000-401 NONE		2000-402 NONE		2000-403 NONE	
Cyclones/Settling Chambers		Electrostatic Precipitators		Wet Collection Systems		Baghouses/Fabric Filters	
2000-404 NONE		2000-405 NONE		2000-406 NONE		2000-407 NONE	
OPERATING PARAMETERS							
1994				Potential			
Natural Gas (Mcf) = 63,537				Natural Gas (Mcf) = 1,752,000			
Max Sulfur Content (%) = 0.01				Max Sulfur Content (%) = 0.01			
Max Ash Content (%) = 0.00				Max Ash Content (%) = 0.00			
HHV Gas (BTU/cf) = 1,000				HHV Gas (BTU/cf) = 1,000			
#6 Fuel Oil (gal) = 0				#6 Fuel Oil (gal) = 11,918,367			
Max Sulfur Content (%) = 0.79				Max Sulfur Content (%) = 0.79			
Max Ash Content (%) = 0.1				Max Ash Content (%) = 0.1			
HHV Fuel Oil (MBTU/gal) = 147				HHV Fuel Oil (MBTU/gal) = 147			
Operation Hours = 500				Operation Hours = 8,760			
EMISSION CALCULATIONS							
Pollutant	Source of Emission Factor	Units of Emission Factor	Emission Factors		Actual Emissions (ton/yr)	PTE 100% Natural Gas (ton/yr)	PTE 100% #6 Fuel Oil (ton/yr)
			Natural Gas	#6 Fuel Oil			
NOx	AP-42(1)	lb/MMCF	550		17	482	
	AP-42(4)	lb/10 ³ gal		67			399
CO	AP-42(1)	lb/MMCF	40		1.3	35	
	AP-42(4)	lb/10 ³ gal		5			30
NMTOC	AP-42(3)	lb/MMCF	1.7		0.05	1.5	
	AP-42(5)	lb/10 ³ gal		0.76			4.5
PM	AP-42(2)	lb/MMCF	3.0		0.10	2.6	
	AP-42(4)	lb/10 ³ gal		10.48			62
PM ₁₀	AP-42(2)	lb/MMCF	3.0		0.07	2.6	
	AP-42(6)	% PM		71			44
SOx	AP-42(1)	lb/MMCF	0.60		0.02	0.53	
	AP-42(4)	lb/10 ³ gal		128.53			701
Antimony							
Arsenic							
Beryllium							
Cadmium							
Chromium							
Cobalt							
Lead	AP-42	lb/10 ¹² BTU	NA	111	0.0000	NA	0.097
Manganese							
Mercury							
Nickel							
Selenium							
Thallium							
Formaldehyde							
POM							

Footnotes

- Section 1.4, Natural Gas Combustion; Table 1.4-2.
- Section 1.4, Natural Gas Combustion; Table 1.4-1.
- Section 1.4, Natural Gas Combustion; Table 1.4-3.
- Section 1.3 Fuel Oil Combustion; Table 1.3-2.
- Section 1.3, Fuel Oil Combustion; Table 1.3-4.
- PM₁₀ is 71% of PM (uncontrolled PM emissions AP-42, Table 1.3-5)

**Unit 2
Public Service Company of Colorado, Zuni Station
Criteria and HAP Emissions**

Stack Identification Code: S003				Unit Code: B003			
Seasonal Fuel Usage (%)				Normal Operation of Unit			Space Heat (%)
Dec-Feb 33	Mar-May 37	Jun-Aug 28	Sep-Nov 2	Hours/Day 24	Days/Week 7	Hours/year 8760	0
BOILER SPECIFICATIONS				STACK DATA			
Furnace Type: Two-Drum Boiler				Height (ft)	250		
Manufacturer: Babcock & Wilcox				Inside Diameter (ft)	12		
Model & Serial #: 17869				Exhaust Flow Rate (ACFM)	Normal 210,000 Max 580,000		
Unit Description: N/A				Exhaust Velocity (fps)	30.96		
First Service or Last Mod. Date: 1953				Calculated or Stack Test (C/ST)	ST		
Max Continuous Rating (MMBTU/hr): 1075 Natural Gas				Exhaust Temperature (F)	500		
1075 #6 Fuel Oil				Exhaust Moisture Content (if modified) (%)	Normal 10 Max 16		
Maximum Hourly Fuel Usage (units/hr)				Orientation of Release	Up		
Fuel Type	Unit	Rate		Rainhat or Other Obstruction	None		
Natural Gas	Mcf/hr	1,075		Control Technology, %			
#6 Fuel Oil	gal/hr	7,313		Control	NOx	PM	SOx
Does the boiler/furnace have control technology (Y/N) N				None	0	0	0
Miscellaneous		Condensers		Adsorbers		Catalytic/Thermal Oxidation	
2000-400	NONE	2000-401	NONE	2000-402	NONE	2000-403	NONE
Cyclones/Settling Chambers		Electrostatic Precipitators		Wet Collection Systems		Baghouses/Fabric Filters	
2000-404	NONE	2000-405	NONE	2000-406	NONE	2000-407	NONE
OPERATING PARAMETERS							
1994				Potential			
Natural Gas (Mcf) = 139,073				Natural Gas (Mcf) = 9,417,000			
Max Sulfur Content (%) = 0.01				Max Sulfur Content (%) = 0.01			
Max Ash Content (%) = 0.00				Max Ash Content (%) = 0.00			
HHV Gas (BTU/cf) = 1,000				HHV Gas (BTU/cf) = 1,000			
#6 Fuel Oil (gal) = 30				#6 Fuel Oil (gal) = 64,061,224			
Max Sulfur Content (%) = 0.79				Max Sulfur Content (%) = 0.79			
Max Ash Content (%) = 0.1				Max Ash Content (%) = 0.1			
HHV Fuel Oil (MBTU/gal) = 147				HHV Fuel Oil (MBTU/gal) = 147			
Operation Hours = 130				Operation Hours = 8,760			
EMISSION CALCULATIONS							
Pollutant	Source of Emission Factor	Units of Emission Factor	Emission Factors		Actual Emissions (ton/yr)	PTE 100% Natural Gas (ton/yr)	PTE 100% #6 Fuel Oil (ton/yr)
			Natural Gas	#6 Fuel Oil			
NOx	AP-42(1)	lb/MMCF	550	67	38	2,590	2,146
	AP-42(4)	lb/10 ³ gal					
CO	AP-42(1)	lb/MMCF	40	5	2.8	188	160
	AP-42(4)	lb/10 ³ gal					
NMTOC	AP-42(3)	lb/MMCF	1.7	1	0.12	8.0	24
	AP-42(5)	lb/10 ³ gal					
PM	AP-42(2)	lb/MMCF	3.0	10.48	0.21	14	336
	AP-42(4)	lb/10 ³ gal					
PM ₁₀	AP-42(2)	lb/MMCF	3.0	71	0.15	14	238
	AP-42(6)	% PM					
SOx	AP-42(1)	lb/MMCF	0.60	128.53	0.044	2.8	3,767
	AP-42(4)	lb/10 ³ gal					
Antimony							
Arsenic							
Beryllium							
Cadmium							
Chromium							
Cobalt							
Lead	AP-42	lb/10 ¹² BTU	NA	111	0.0000	NA	0.52
Manganese							
Mercury							
Nickel							
Selenium							
Thallium							
Formaldehyde							
POM							

Footnotes
1. Section 1.4, Natural Gas Combustion, Table 1.4-2.
2. Section 1.4, Natural Gas Combustion, Table 1.4-1.
3. Section 1.4, Natural Gas Combustion, Table 1.4-3.
4. Section 1.3 Fuel Oil Combustion, Table 1.3-2.
5. Section 1.3, Fuel Oil Combustion, Table 1.3-4.
6. PM₁₀ is 71% of PM (uncontrolled PM emissions AP-42, Table 1.3-5)

Robinson Brick

FOR THE RECORD

January 31, 2001

BY: Mike Jensen

Ref: Robinson Brick FID 0311447 97OPDE189

SUBJECT: PM10 PTE Review

On Friday, January 26, 2001, Mike Silverstein, APCD, called and asked for the PTE numbers for Robinson Brick. I gave him the numbers from the TRD. A copy of that page of the TRD is attached to this review for future reference as needed.

Gerry Dilley (303-629-5450 X240) from the RAQC called yesterday with a request for information about how the PTE for the PM10 for Robinson Brick was calculated. I reviewed the file and compiled the following information. The process design rates are taken from the Title V submittal. A copy of the summary page is attached to this review for future reference as needed. Emission factors shown were taken from the Title V permit. Reg 1 sets a particulate matter hourly limit for some sources. This limit would be an upper boundary in that while PM10 may be a fraction of the PM, it can not exceed the PM.

F001/F005 Loader/Storage Piles/Unpaved Roads

This is all fugitive dust and not included in the facility PTE

Material Transfer: $0.1 \times 0.35 = 0.04$ TPY

Storage Piles: $24.9 \times 0.35 = \underline{8.72}$ TPY

Total: 8.76 TPY

F002 Primary Crusher

Reg 1 = $17.31(90)^{0.16} = 35.56$ lb/hr

$35.56 \text{ lb/hr} \times 8760 \text{ hr/yr} \times \text{ton}/2000 \text{ lb} = 35.56 \times 4.38 = 155.8$ TPY

Design Rate: $90 \text{ ton/hr} \times 0.059 \text{ lb/ton} \times 4.38 \text{ hr-ton/yr-lb} = 23.25$ TPY

PTE = 23.3 TPY

F003 Grinding/Screening

Reg 1 = $17.31(90)^{0.16} = 35.56$ lb/hr

$35.56 \text{ lb/hr} \times 4.38 \text{ hr-ton/yr-lb} = 155.8$ TPY

Design Rate: $90 \text{ ton/hr} \times 0.0265 \text{ lb/ton} \times 4.38 \text{ hr-ton/yr-lb} = 10.45$ TPY

Permit Limit: 4.7 TPY

PTE = 4.7 TPY

F004 Conveyor

Reg 1 = $17.31(90)^{0.16} = 35.56$ lb/hr
35.56 lb/hr X 4.38 hr-ton/yr-lb = 155.8 TPY

Design Rate: 90 ton/hr X 0.00029 lb/ton X 4.38 hr-ton/yr-lb = 0.11 TPY **PTE = 0.11**
TPY

S001 Rotary Dryer

Reg 1 = $17.31(35)^{0.16} = 30.57$ lb/hr
30.57 lb/hr X 4.38 hr-ton/yr-lb = 133.9 TPY

Design Rate: 35 ton/hr X 0.16 lb/ton X 4.38 hr-ton/yr-lb = 24.53 TPY **PTE = 24.5**
TPY

S002 – S005 Two Tunnel Dryers & two kilns

Reg 1 = $3.59(13.4)^{0.62} = 17.9$ lb/hr
17.9 lb/hr X 4.38 hr-ton/yr-lb = 78.59 TPY per line X 2 = 157.18 TPY

From Title V = 199,000 ton/yr X 0.87 lb/ton X ton/2000 lb = 86.6 TPY

Permit Limit = 130.8 TPY **PTE = 130.8**
TPY

S006 Rotary Calciner

Reg 1 = $3.59(10.0)^{0.62} = 14.9$ lb/hr
14.9 lb/hr X 4.38 hr-ton/yr-lb = 65.5 TPY

Design Rate: 10 ton/hr X 0.3 lb/ton X 4.38 hr-ton/yr-lb = 13.14 TPY **PTE = 13.14**
TPY

PTE SUMMARY

F002	Primary Crusher	23.3 TPY
F003	Grinding/Screening	4.7
F004	Conveyor	0.11
S001	Rotary Dryer	24.5
S002-S005	Two Tunnel Dryers and kilns	130.8
S006	Rotary Calciner	<u>13.1</u>
TOTAL		196.5 TPY

Rocky Mountain Bottle Company

Trigen-Colorado Energy Corporation

Facility-wide emissions are as follows:

	POTENTIAL TO EMIT, TONS PER YEAR						
	PM	PM ₁₀	SO ₂	NO _x	VOC	CO	HAPs
B001 - 288 MMBtu/hr	/	/	/	/	/	/	/
NG	9.4	9.4	0.74	346.3	10.8	103.9	
#2 FO	18.02	9.01	410.2	216.3	1.8	45.1	
B002 - 288 MMBtu/hr	/	/	/	/	/	/	/
NG	9.4	9.4	0.74	346.3	10.8	103.9	
#2 FO	18.02	9.01	410.2	216.3	1.8	45.1	
B003 - 225 MMBtu/hr, Coal	2852.8	570.6	1312.33	380.4	2.16	216.1	
B004 - 360 MMBtu/hr,	/	/	/	/	/	/	/
Permit	158.0	158.0	1392.0	1104.0	19.21	88.30	
Coal*	5268.55	1218.92	2650.05	639.36	4.86	39.55	
NG	16.45	16.45	1.30	367.92	18.83	51.94	
#2 FO	28.03	14.02	638.15	336.38	2.80	70.08	
B005 - 650 MMBtu/hr,	/	/	/	/	/	/	/
Permit	285.0	285.0	3416.0	995.0	9.50	103.1	
Coal*	11084.15	2556.71	5557.73	1346.16	10.02	82.62	
NG	21.21	21.21	1.67	474.50	24.28	66.99	
#2 FO	40.67	20.34	925.89	488.06	4.07	101.68	
M001/C004 - Rail car dumper to hoppers	51.6	51.6					
M001/C005 - Dumper to transfer conveyor							
M001/C006 - Conveyor to Unit 4 silos							
M001/C008 - Conveyor to Unit 5 silos	22.7	22.7					

RECEIVED

FEB 22 2000

AIR POLLUTION CONTROL DIVISION
STATIONARY SOURCES PROGRAM

Unit 1							
TRIGEN-COLORADO ENERGY CORPORATION							
Criteria and HAP Emissions from Natural Gas or Fuel Oil							
Stack Identification Code: S001			Unit Code: B001				
Seasonal Fuel Usage (%)				Normal Operation of Unit		Space Heat (%)	
Dec-Feb	Mar-May	Jun-Aug	Sep-Nov	Hours/Day	Days/Week	Hours/year	
25	25	25	25	24	7	8760	
BOILER SPECIFICATIONS				STACK DATA			
Furnace Type: Wall Fired				Height (ft)	130		
Manufacturer: Combustion Engineering				Inside Diameter (ft)	8		
Model & Serial #: CE-VU40, 17047				Exhaust Flow Rate (ACFM)	Normal 110,000 Max 120,637		
Unit Description: External Combustion Wall-Fired Boiler				Exhaust Velocity (fps) at MCR	40.00		
First Service or Last Mod. Date: 1967				Calculated or Stack Test (CST)	ST		
Maximum Continuous Rating: 288 Natural Gas or #2 Fuel Oil (MMBTU/HR)				Exhaust Temperature (F)	380		
Maximum Hourly Fuel Usage (units/hr)				Exhaust Moisture Content (if modified) (%)	Normal 10 Max 16		
Fuel Type	Unit	Rate		Orientation of Release	Up		
Natural Gas	Mcf/hr	271		Rainhat or Other Obstruction	None		
#2 Fuel Oil	gal/hr	2,075		Control Technology, %			
Does the boiler/furnace have control technology (Y/ N)				Control Devic	NOx	PM	SOx
				None	0	0	0
Miscellaneous		Condensers	Adsorbers	Catalytic/Thermal Oxidation			
2000-400	NONE	2000-401 NONE	2000-402 NONE	2000-403	NONE		
Cyclones/Settling Chambers		Electrostatic Precipitators	Wet Collection Systems	Baghouses/Fabric Filters			
2000-404	NONE	2000-405 NONE	2000-406 NONE	2000-407	NONE		
OPERATING PARAMETERS							
1994 Revised				Potential			
Btu corrected Natural Gas (Mcf) =	210,746		Btu corrected Natural Gas (Mcf) =	2,373,960			
Avg. Sulfur Content (%) =	0.01		Avg. Sulfur Content (%) =	0.01			
Avg. Ash Content (%) =	0.00		Avg. Ash Content (%) =	0.00			
HHV Gas (Btu/SCF) =	1,064		HHV Gas (Btu/SCF) =	1,064			
#2 Fuel Oil (gal) =	0		#2 Fuel Oil (gal) =	18,177,000			
Btu corrected Fuel Oil (gals) =	0		Btu corrected Fuel Oil (gals) =	18,021,197			
Avg. Sulfur Content (%) =	0.29		Avg. Sulfur Content (%) =	0.29			
Avg. Ash Content (%) =	0.01		Avg. Ash Content (%) =	0.01			
HHV Oil (Btu/gal) =	138,800		HHV Oil (Btu/gal) =	138,800			
Operation Hours =	8,544		Operation Hours =	8,760			
EMISSION CALCULATIONS							
Pollutant	Source of Emission	Units of Emission	Emission Factors		Actual Emissions (ton/yr)	PTE 100% Natural Gas (ton/yr)	PTE 100% #2 Fuel Oil (ton/yr)
			Natural Gas	#2 Fuel Oil			
NOx	AP-42[8]	lb/MMCF	280		29.50	332	
	AP-42[10]	lb/10 ³ gal		24	0.0		216
	Total Calculated Emissions:					29.50	
CO	AP-42[8]	lb/MMCF	84		8.85	100	
	AP-42[10]	lb/10 ³ gal		5	0.00		45
	Total Calculated Emissions:					8.851	
TNMOC	AP-42[9]	lb/MMCF	8.7	0.20	0.9167	10.33	
	AP-42[11]	lb/10 ³ gal			0.000		2
	Total Calculated Emissions:					0.917	
PM	AP-42[9]	lb/MMCF	7.6		0.8008	9.02	
	AP-42[10]	lb/10 ³ gal		2	0.0000		18
	Total Calculated Emissions:					0.8008	
PM10	AP-42[9]	lb/MMCF	7.6		0.8008	9.02	
	AP-42[12]	lb/10 ³ gal		1	0.0000		9
	Total Calculated Emissions:					0.8008	
SOx	AP-42[9]	lb/MMCF	0.60		0.063	0.71	
	AP-42[10]	lb/10 ³ gal		45.53	0.000		410
	Total Calculated Emissions:					0.063	

RECEIVED

FEB 22 2000

AIR POLLUTION CONTROL DIVISION
STATIONARY SOURCES PROGRAM

Unit 2 TRIGEN-COLORADO ENERGY CORPORATION Criteria and HAP Emissions from Natural Gas or Fuel Oil									
Stack Identification Code: S002					Unit Code: B002				
Seasonal Fuel Usage (%)				Normal Operation of Unit				Space Heat (%)	
Dec-Feb	Mar-May	Jun-Aug	Sep-Nov	Hours/Day	Days/Week	Hours/year			
25	25	25	25	24	7	8760	0		
BOILER SPECIFICATIONS					STACK DATA				
Furnace Type: Wall Fired					Height (ft) 130				
Manufacturer: Combustion Engineering					Inside Diameter (ft) 8				
Model & Serial #: CE-VU40, 17049					Exhaust Flow Rate (ACFM)				
Unit Description: External Combustion Wall-Fired Boiler					Normal 110,000 Max 120,637				
First Service or Last Mod. Date: 1967					Exhaust Velocity (fpe) at MCR 40.00				
Maximum Continuous Rating: 288 Natural Gas or #2 Fuel Oil					Calculated or Stack Test (C/ST) ST				
Maximum Hourly Fuel Usage (units/hr)					Exhaust Temperature (F) 380				
					Exhaust Moisture Content (if modified) (%)				
Fuel Type					Normal 10 Max 16				
Natural Gas					Orientation of Release Up				
#2 Fuel Oil					Rainhat or Other Obstruction None				
Does the boiler/furnace have control technology (Y/ N) N					Control Technology, %				
					Control Device NOx PM SOx				
					None 0 0 0				
Miscellaneous		Condensers		Adsorbers		Catalytic/Thermal Oxidation			
2000-400 NONE		2000-401 NONE		2000-402 NONE		2000-403 NONE			
Cyclones/Settling Chambers		Electrostatic Precipitators		Wet Collection Systems		Baghouses/Fabric Filters			
2000-404 NONE		2000-405 NONE		2000-406 NONE		2000-407 NONE			
OPERATING PARAMETERS									
1994 Revised					Potential				
Btu corrected Natural Gas (Mcf) = 200,792					Btu corrected Natural Gas (Mcf) = 2,372,960				
Avg. Sulfur Content (%) = 0.01					Avg. Sulfur Content (%) = 0.01				
Avg. Ash Content (%) = 0.00					Avg. Ash Content (%) = 0.00				
HHV Gas (Btu/SCF) = 1,064					HHV Gas (Btu/SCF) = 1,064				
#2 Fuel Oil (gal) = 291,439					#2 Fuel Oil (gal) = 18,177,000				
Btu corrected Fuel Oil (gals) = 288,941					Btu corrected Fuel Oil (gals) = 18,021,197				
Avg. Sulfur Content (%) = 0.29					Avg. Sulfur Content (%) = 0.29				
Avg. Ash Content (%) = 0.01					Avg. Ash Content (%) = 0.01				
HHV Oil (Btu/gal) = 138,800					HHV Oil (Btu/gal) = 138,800				
Operation Hours = 7,920					Operation Hours = 8,760				
EMISSION CALCULATIONS									
Unit 2									
Pollutant	Source of Emission Factor/CEM	Units of Emission Factor	Emission Factors		Actual Emissions (ton/yr)	PTE 100% Natural Gas (ton/yr)	PTE 100% #2 Fuel Oil (ton/yr)		
			Natural Gas	#2 Fuel Oil					
NOx	AP-42[8]	lb/MMCF	280		28.1	332			
	AP-42[10]	lb/10 ³ gal		24	3.5		216		
	Total Calculated Emissions:					31.58			
CO	AP-42[8]	lb/MMCF	84		8.43	100			
	AP-42[10]	lb/10 ³ gal		5	0.72		45		
	Total Calculated Emissions:					9.156			
TNMOC	AP-42[9]	lb/MMCF	8.7		0.8734	10			
	AP-42[11]	lb/10 ³ gal		0.20	0.029		2		
	Total Calculated Emissions:					0.902			
PM	AP-42[9]	lb/MMCF	7.6		0.7630	9			
	AP-42[10]	lb/10 ³ gal		2	0.2889		18		
	Total Calculated Emissions:					1.052			
PM10	AP-42[9]	lb/MMCF	7.6		0.7630	9			
	AP-42[12]	lb/10 ³ gal		1	0.1445		9		
	Total Calculated Emissions:					0.907			
SOx	AP-42[9]	lb/MMCF	0.60		0.060	1			
	AP-42[10]	lb/10 ³ gal		45.53	6.578		410		
	Total Calculated Emissions:					6.638			

RECEIVED

FEB 22 2000

AIR POLLUTION CONTROL DIVISION
STATIONARY SOURCES PROGRAM

Unit 3							
TRIGEN-COLORADO ENERGY CORPORATION							
Criteria and HAP Emissions							
Stack Identification Code: S003				Unit Code: B003			
Seasonal Fuel Usage (%)				Normal Operation of Unit			
Dec-Feb	Mar-May	Jun-Aug	Sep-Nov	Hours/Day	Days/Week	Hours/year	Space Heat (%)
25	25	25	25	24	7	8,760	0
BOILER SPECIFICATIONS				STACK DATA			
Furnace Type: Traveling Grate Spreader-Stoker				Height (ft) 130			
Manufacturer: Combustion Engineering				Inside Diameter (ft) 8			
Model & Serial #: CE-VU40, 17051				Exhaust Flow Rate (acfm)			
Unit Description: External Combustion Coal-fired Stoker Boiler				Normal 100,000 Max 105,558			
First Service or Last Mod. Date: 1981				Exhaust Velocity (fps) at MCR 35.00			
Maximum Continuous Rating: 225.0 Coal (MMBTU/HR)				Calculated or Stack Test (C/ST) ST			
				Exhaust Temperature (F) 360			
Maximum Hourly Fuel Usage (units/hr)				Exhaust Moisture Content (if modified) (%)			
Fuel Type	Unit	Rate		Normal NA Max NA			
SubBituminous Coal	ton/hr	9.90		Orientation of Release Up			
Does the boiler/furnace have control technology (Y/ N)				Rainhat or Other Obstruction None			
				Control Technology and Efficiency (%)			
				Control Devi NOx PM SOx			
				Baghouse 0 99.9 0			
Miscellaneous Condensers				Adsorbers Catalytic/Thermal Oxidation			
2000-400 NONE	2000-401 NONE			2000-402 NONE	2000-403 NONE		
Cyclones/Settling Chambers Electrostatic Precipitators				Wet Collection Systems Baghouses/Fabric Filters			
2000-404 NONE	2000-405 NONE			2000-406 NONE	2000-407 C001		
OPERATING PARAMETERS							
1994 Revised				Potential			
Sub Bit Coal Fired (tons) = 47,876				Sub Bit Coal Fired (tons) = 86,724			
Avg. Sulfur Content (%) = 0.45				Avg. Sulfur Content (%) = 1			
Avg. Ash Content (%) = 7.00				Avg. Ash Content (%) = 7			
HHV Coal (Btu/lb) = 11,400				HHV Coal (Btu/lb) = 11,400			
Operation Hours = 7,752				Operation Hours = 8,760			
EMISSION CALCULATIONS							
Unit 3							
Pollutant	Source of Emission Factor	Units of Emission Factor	Emission Factors			Actual Emissions (tpy)	PTE 100% Coal (tpy)
			Coal				
NOx	AP-42[1]	lb/ton	8.8			211	382
CO	AP-42[1]	lb/ton	5.00			120	217
NMTOC	AP-42[1]	lb/ton	0.05			1	2
PM	AP-42[1]	lb/ton	66.00			2	121
PM10	AP-42[2]	lb/ton	13.20			0	111
SOx	AP-42[1]	lb/ton	15.8			377	1,774

Unit 4									
TRIGEN-COLORADO ENERGY CORPORATION									
Criteria and HAP Emissions from Coal, Alcohol, and Waste Oil									
Stack Identification Code: S004					Unit Code: B004				
Seasonal Fuel Usage (%)					Normal Operation of Unit			Space Heat (%)	
Dec-Feb	Mar-May	Jun-Aug	Sep-Nov	Hours/Day	Days/Week	Hours/year			
25	25	25	25	24	7	8,760	0		
BOILER SPECIFICATIONS					STACK DATA				
Furnace Type: Tangential Firing					Height (ft) 130				
Manufacturer: Combustion Engineering					Inside Diameter (ft) 8				
Model & Serial CE-VU40, 21321					Exhaust Flow Rate (acfm)				
Unit Description External Combustion Tangential Fired Boiler					Normal 150,000 Max 174,924				
First Service or Last Mod. Date 1976					Exhaust Velocity (fps) at MCR 58.00				
Maximum Continuous Rating: 371.0 Coal, Natural Gas, & Fuel Oil					Calculated or Stack Test (C/ST) ST				
					Exhaust Temperature (F) 380				
Maximum Hourly Fuel Usage (units/hr)					Exhaust Moisture Content (if modified) (%)				
Fuel Type	Unit	Rate			Normal 12 Max 13				
Subbituminous Coal	ton/hr	17.14			Orientation of Release Up				
Waste Oil	gal/hr	11			Rainhat or Other Obstruction None				
Alcohol	gal/hr	32.0			Control Technology and Efficiency (%)				
Does the boiler/furnace have control technology Y					Control Devi NOx PM SOx				
Miscellaneous					Baghouse 0 99.9 0				
Condensers					Adsorbers Catalytic/Thermal Oxidation				
2000-400 NONE 2000-401 NONE					2000-402 NONE 2000-403 NONE				
Cyclones/Settling Chambers Electrostatic Precipitators					Wet Collection Systems Baghouses/Fabric Filters				
2000-404 NONE 2000-405 NONE					2000-406 NONE 2000-407 C002				
OPERATING PARAMETERS									
1994 Revised					Potential				
Sub Bit Coal Fired (tons) = 124,107					Sub Bit Coal Fired (tons) = 150,171				
Avg. Sulfur Content (%) = 0.45					Avg. Sulfur Content (%) = 1				
Avg. Ash Content (%) = 7.00					Avg. Ash Content (%) = 7				
HHV Coal (Btu/lb) = 11,400					HHV Coal (Btu/lb) = 11,400				
Alcohol (gals) = 283,445					Alcohol (gals) = 283,445				
Avg. Alcohol Sulfur Content (%) = 0.34					Avg. Alcohol Sulfur Content (%) = 0.34				
Avg. Alcohol Ash Content (%) = 0.1					Avg. Alcohol Ash Content (%) = 0.1				
HHV Alcohol (Btu/ton) = 2,00E+06					HHV Alcohol (Btu/ton) = 2,00E+06				
Waste Oil Fired (gals) = 15,703					Waste Oil Fired (gals) = 100,000				
Avg. Sulfur Content (%) = 0.5					Avg. Sulfur Content (%) = 0.5				
Avg. Ash Content (%) = 0.65					Avg. Ash Content (%) = 0.65				
HHV Oil (Btu/gal) = 149,000					HHV Oil (Btu/gal) = 149,000				
Operation Hours = 8,208					Operation Hours = 8,760				
EMISSION CALCULATIONS									
Unit 4									
Pollutant	Source of Emission	Units of Emission	Emission Factors			Actual Emissions (tpy)	PTE 100% Coal (tpy)	PTE Coal and Alcohol (tpy)	PTE Coal, Alcohol, Waste Oil (tpy)
			Coal	Alcohol	Waste Oil				
NOx	AP-42[1]	lb/ton	8.4	21		521	1,104		
	AP-42[9]	lb/10 ³ gal			19.0	3		1,104	
	AP-42(3)	lb/10 ³ gal				0			1,104
	CEM(5)	NA	NA	NA	NA	524		NA	NA
Total Calculated this sheet:						644.01			
CO	AP-42[1]	lb/ton	0.5	3.6		31.0	88.00		
	AP-42[9]	lb/10 ³ gal			5.0	1		88.00	
	AP-42(3)	lb/10 ³ gal				0.04			88.00
	CEM(5)	NA	NA	NA	NA	32			
Total Calculated this sheet:						64.04			
NMTOC	AP-42[1]	lb/ton	0.06	0.4		3.7	5.30		
	AP-42[9]	lb/10 ³ gal			1.00	0.1		5.30	
	AP-42(3)	lb/10 ³ gal				0.0			5.30
	CEM(5)	NA	NA	NA	NA	3.8			
Total Calculated this sheet:						3.8			
PM	AP-42[1]	lb/ton	70	0.600		4.3	158.00		
	AP-42[9]	lb/10 ³ gal			41.60	0.0		158.00	
	AP-42[8]	lb/10 ³ gal				0.0			158.00
	CEM(5)	NA	NA	NA	NA	4.3			
Total Calculated this sheet:						4.3			
PM10	AP-42[4]	lb/ton	16.1	0.60		0.7	158.00		
	AP-42[9]	lb/10 ³ gal			33.2	0.0		158.00	
	AP-42[8]	lb/10 ³ gal				0.0			158.00
	CEM(5)	NA	NA	NA	NA	0.7			
Total Calculated this sheet:						0.7			
SOx	AP-42[1]	lb/ton	15.75	0.03		977	1,892.00		
	AP-42(2)	lb/10 ³ gal			73.50	0		1,892.00	
	AP-42(3)	lb/10 ³ gal				0			1,892.00
	CEM(5)	NA	NA	NA	NA	977		NA	NA
Total Calculated this sheet:						898.30			

RECEIVED

FEB 22 2000

AIR POLLUTION CONTROL DIVISION
STATIONARY SOURCES PROGRAM

RECEIVED

FEB 22 2000

Unit 5									
TRIGEN-COLORADO ENERGY CORPORATION					AIR POLLUTION CONTROL DIVISION				
Criteria and HAP Emissions from Coal, Alcohol, and Waste Oil					STATIONARY SOURCES PROGRAM				
Stack Identification Code: S005					Unit Code: B005				
Seasonal Fuel Usage (%)					Normal Operation of Unit				
Dec-Feb	Mar-May	Jun-Aug	Sep-Nov		Hours/Day	Days/Week	Hours/year	Space Heat (%)	
25	25	25	25		24	7	8,760	0	
BOILER SPECIFICATIONS					STACK DATA				
Furnace Type: Tangential Firing					Height (ft): 200				
Manufacturer: Combustion Engineering					Inside Diameter (ft): 13				
Model & Serial: CE-VU40, 27576					Exhaust Flow Rate (acfm): Normal: 290,000 Max: 302,630				
Unit Description: External Combustion Tangential Fired Boiler					Exhaust Velocity (fps) at MCR: 38.00				
First Service or Last Mod. Date: 1979					Calculated or Stack Test (C/ST): ST				
Maximum Continuous Rating: 652.5 Coal, Natural Gas, & Fuel Oil					Exhaust Temperature (F): 380				
MMBTU/HR					Exhaust Moisture Content (if modified) (%)				
Maximum Hourly Fuel Usage (units/hr)					Normal: 12 Max: 13				
Fuel Type	Unit	Rate				Orientation of Release: Up			
Subbituminous Coal	ton/hr	36.11				Rainhat or Other Obstruction: None			
Waste Oil	gal/hr	23							
Alcohol	gal/hr	129.4							
Does the boiler/furnace have control technology: Y					Control Technology and Efficiency (%)				
					Control Device: NOx PM SOx				
					Baghouse: 0 99.9 0				
Miscellaneous					Cyclones/Thermal Oxidation				
2000-400	NONE	2000-401	NONE	2000-402	NONE	2000-403	NONE		
Cyclones/Settling Chambers					Wet Collection Systems				
2000-404	NONE	2000-405	NONE	2000-406	NONE	2000-407	C003		
OPERATING PARAMETERS									
1994 Revised					Potential				
Sub Bit Coal Fired (tons) = 234,930					Sub Bit Coal Fired (tons) = 316,333				
Avg Sulfur Content (%) = 0.45					Avg Sulfur Content (%) = 1				
Avg Ash Content (%) = 7.00					Avg Ash Content (%) = 7				
HHV Coal (Btu/lb) = 11,400					HHV Coal (Btu/lb) = 11,400				
Alcohol (gals) = 1,133,782					Alcohol (gals) = 1,133,782				
Avg Alcohol Sulfur Content (%) = 0.34					Avg Alcohol Sulfur Content (%) = 0.34				
Avg Alcohol Ash Content (%) = 0.1					Avg Alcohol Ash Content (%) = 0.1				
HHV Alcohol (Btu/ton) = 2,000,000					HHV Alcohol (Btu/ton) = 2,000,000				
Waste Oil Fired (gals) = 31,407					Waste Oil Fired (gals) = 200,000				
Avg Sulfur Content (%) = 0.5					Avg Sulfur Content (%) = 0.5				
Avg Ash Content (%) = 0.65					Avg Ash Content (%) = 0.65				
HHV Oil (Btu/gal) = 149,000					HHV Oil (Btu/gal) = 149,000				
Operation Hours = 8,760					Operation Hours = 8,760				
EMISSION CALCULATIONS									
Unit 5									
Pollutant	Source of Emission	Units of Emission	Emission Factors			Actual Emissions (tpy)	PTE 100% Coal (tpy)	PTE Coal and Alcohol (tpy)	PTE Coal, Alcohol, Waste Oil (tpy)
			Coal	Alcohol	Waste Oil				
			Factor/CEM	Factor					
NOx	AP-42[1]	lb/ton	8.4			987	1,993		
	AP-42[9]	lb/10 ³ gal		21		11.90		1,993	
	AP-42(3)	lb/10 ³ gal			19.0	0.30			1,993
	CEM(5)	NA	NA	NA	NA	999	NA	NA	NA
Total Calculated this sheet:						707.08			
CO	AP-42[1]	lb/ton	0.50			58.73	103.10		
	AP-42 [9]	lb/10 ³ gal		3.6		2.04		103.10	
	AP-42(3)	lb/10 ³ gal			5.0	0.08			103.10
	CEM(5)	NA	NA	NA	NA	61			
Total Calculated this sheet:						61			
NMTOC	AP-42[1]	lb/ton	0.06			7.05	9.50		
	AP-42[9]	lb/10 ³ gal		0.4		0.23		9.50	
	AP-42(3)	lb/10 ³ gal			1.00	0.02			9.50
	CEM(5)	NA	NA	NA	NA	7.3			
Total Calculated this sheet:						7.3			
PM	AP-42[1]	lb/ton	70.00			8.22	285.00		
	AP-42[9]	lb/10 ³ gal		0.00		0.00		285.00	
	AP-42[8]	lb/10 ³ gal			41.60	0.00			285.0
	CEM(5)	NA	NA	NA	NA	8.2			
Total Calculated this sheet:						8.2			
PM10	AP-42[4]	lb/ton	16.10			1.89	285.00		
	AP-42[9]	lb/10 ³ gal		0.60		0.00		285.00	
	AP-42[8]	lb/10 ³ gal			33.2	0.00			285.0
	CEM(5)	NA	NA	NA	NA	1.9			
Total Calculated this sheet:						1.9			
SOx	AP-42[1]	lb/ton	15.75			1,850	3,416.00		
	AP-42(2)	lb/10 ³ gal		0.03		0.02		3,416.00	
	AP-42(3)	lb/10 ³ gal			73.50	0.00			3,416.00
	CEM(5)	NA	NA	NA	NA	1,850			
Total Calculated this sheet:						1,850			

UDS Refinery (previously Colorado Refining Company)

COLORADO REFINING COMPANY

A SUBSIDIARY OF TOTAL PETROLEUM, INC.

5800 BRIGHTON BOULEVARD
COMMERCE CITY, COLORADO 80022

TELEPHONE 303 295-4500

**CERTIFIED MAIL
RETURN RECEIPT REQUESTED
HAND DELIVERED**

January 17, 2000

Mr. Long Nguyen
Air Pollution Control Division
Colorado Department of Public Health and Environment
4300 Cherry Creek Drive South
Denver, Colorado 80246-1530

RE: Emission Calculation – PTE for NO_x, SO_x, PM₁₀

Dear Mr. Nguyen:

Enclosed please find Colorado Refining Company's (CRC) potential to emit (PTE) calculations for the sources that you had requested.

If you require more information or have any questions or comments, please call me at (303) 227-2414.

Sincerely,



Mark Suyama
Environmental Engineer

Enclosure

RECEIVED
JAN 23 2001
AIR POLLUTION CONTROL
STATIONARY SOURCES PROGRAM

CRUDE & VACUUM HEATERS

Potential To Emit

Design Ratings

Crude Heater	88 MMBTU/hr
Vacuum Heater	31 MMBTU/hr

Emission Factors

Crude Heater

NOx	85 lb/MMscf	Vendor
SO ₂	120 ppm/H ₂ S	Fuel Gas Maximum
PM10	13.7 lb/MMscf	AP-42 (Table 1.4-3 Small Industrial Boilers - Low NOx Burners)

Vacuum Heater

NOx	0.075 lb/MMBTU	Vendor
SO ₂	120 ppm/H ₂ S	Fuel Gas Maximum
PM10	13.7 lb/MMscf	AP-42 (Table 1.4-3 Small Industrial Boilers - Low NOx Burners)

Emission Calculations

Crude Heater

NOx: $(88 \text{ MMBTU/hr})(8760 \text{ hr/yr})(10^6 \text{ BTU/MMBTU})(\text{Scf}/1000\text{BTU})(\text{MMscf}/106 \text{ Scf})(85 \text{ lb/MMscf})(\text{Ton}/2000 \text{ lb}) = 32.8 \text{ TPY}$
SO₂: $(88 \text{ MMBTU/hr})(\text{MMscf}/450 \text{ MMBTU})(120 \text{ ft}^3/\text{MMscf})(\text{lb mol}/379 \text{ ft}^3)(64 \text{ lb SO}_2/\text{lb mol})(8760 \text{ hr/yr})(\text{Ton}/2000 \text{ lb}) = 17.3 \text{ TPY}$
PM10: $(88 \text{ MMBTU/hr})(8760 \text{ hr/yr})(10^6 \text{ BTU/MMBTU})(\text{Scf}/1000 \text{ BTU})(\text{MMscf}/106 \text{ Scf})(13.7 \text{ lb/MMscf})(\text{Ton}/2000\text{lb}) = 5.2 \text{ TPY}$

Vacuum Heater

NOx: $(31 \text{ MMBTU/hr})(0.075 \text{ lb/MMBTU})(\text{Ton}/2000 \text{ lb})(8760 \text{ hr/yr}) = 10.1 \text{ TPY}$
SO₂: $(31 \text{ MMBTU/hr})(\text{MMscf}/450 \text{ MMBTU})(120 \text{ ft}^3/\text{MMscf})(\text{lb mol}/379 \text{ ft}^3)(64 \text{ lb SO}_2/\text{lb mol})(8760 \text{ hr/yr})(\text{Ton}/2000 \text{ lb}) = 6.1 \text{ TPY}$
PM10: $(31 \text{ MMBTU/hr})(8760 \text{ hr/yr})(10^6 \text{ BTU/MMBTU})(\text{Scf}/1000 \text{ BTU})(\text{MMscf}/106 \text{ Scf})(13.7 \text{ lb/MMscf})(\text{Ton}/2000\text{lb}) = 1.8 \text{ TPY}$

NOx ⇒ 42.9 ✓

SO₂ ⇒ 17.3 + 6.1 ⇒ 23.4 ✓

PM₁₀ ⇒ 7.0 ✓

BLACK OIL HEATER

Potential To Emit

Design Ratings

BLACK OIL HEATER 8.1 MMBTU/hr

Emission Factors

Black Oil Heater

NOx	100 lb MMscf	AP-42 (Table 1.4-2)
SO2	120 ppm/H2S	Fuel Gas Maximum
PM10	12 lb/MMscf	AP-42 (Table 1.4-1)

Emission Calculations

Black Oil Heater

NOx: $(8.1 \text{ MMBTU/hr})(0.11 \text{ lb/MMBTU})(\text{Ton}/2000 \text{ lb})(8760 \text{ hr/yr}) = 3.8 \text{ TPY}$

SO2: $(8.1 \text{ MMBTU/hr})(\text{MMscf}/450 \text{ MMBTU})(120 \text{ ft}^3/\text{MMscf})(\text{lb mol}/379 \text{ ft}^3)(64 \text{ lb SO}_2/\text{lb mol})(8760 \text{ hr/yr})(\text{Ton}/2000 \text{ lb}) = 1.6 \text{ TPY}$

PM10: $(8.1 \text{ MMBTU/hr})(0.005 \text{ lb/MMscf})(\text{Ton}/2000 \text{ lb})(8760 \text{ hr/yr}) = 0.2 \text{ TPY}$

REFORMER HEATERS

Potential To Emit

Design Ratings

Reformer Heaters 161 MMBTU/hr

Emission Factors

Reformer Heaters

NOx	0.075 lb/MMBTU	Source Test Data
SO2	120 ppm/H2S	Fuel Gas Maximum
PM10	13.7 lb/MMscf	AP-42 (Table 1.4-3 Small Industrial Boilers - Low NOx Burners (6.2 + 7.5))

Emission Calculations

Reformer Heaters

NOx: $(161 \text{ MMBTU/hr})(0.075 \text{ lb/MMBTU})(\text{Ton}/2000 \text{ lb})(8760 \text{ hr/yr}) = 52.8 \text{ TPY}$

SO2: $(161 \text{ MMBTU/hr})(\text{MMscf}/450 \text{ MMBTU})(120 \text{ ft}^3/\text{MMscf})(\text{lbmol}/379 \text{ ft}^3)(64 \text{ lb SO}_2/\text{lbmol})(8760 \text{ hr/yr})(\text{Ton}/2000 \text{ lb}) = 31.8 \text{ TPY}$

PM10: $(161 \text{ MMBTU/hr})(8760 \text{ hr/yr})(10^6 \text{ BTU/MMBTU})(\text{Scf}/1000 \text{ BTU})(\text{MMscf}/10^6 \text{ Scf})(13.7 \text{ lb/MMscf})(\text{Ton}/2000 \text{ lb}) = 9.7 \text{ TPY}$

UTILITIES - BOILERS

Potential To Emit

Design Ratings

Utilities 225 MMBTU/hr

Emission Factors

Utilities

NOx	140 lb/10 ⁶ ft ³	AP-42 (Table 1.4-2 Small Industrial Boilers)
SO ₂	120 ppm/H ₂ S	Fuel Gas Maximum
PM ₁₀	13.7 lb/MMscf	AP-42 (Table 1.4-3 Small Industrial Boilers - Low NOx Burners (6.2 + 7.5))

Emission Calculations

Utilities

NOx: $(225 \text{ MMBTU/hr})(0.075 \text{ lb/MMBTU})(\text{Ton}/2000 \text{ lb})(8760 \text{ hr/yr}) = 73.9 \text{ TPY}$

SO₂: $(225 \text{ MMBTU/hr})(\text{MMscf}/1000 \text{ MMBTU})(120 \text{ ft}^3/\text{MMscf})(\text{lbmol}/379 \text{ ft}^3)(64 \text{ lb SO}_2/\text{lbmol})(8760 \text{ hr/yr})(\text{Ton}/2000 \text{ lb}) = 19.9 \text{ TPY}$

PM₁₀: $(225 \text{ MMBTU/hr})(8760 \text{ hr/yr})(10^6 \text{ BTU/MMBTU})(\text{Scf}/1000 \text{ BTU})(\text{MMscf}/10^6 \text{ Scf})(13.7 \text{ lb/MMscf})(\text{Ton}/2000 \text{ lb}) = 13.5 \text{ TPY}$

REFINERY FLARE

Potential To Emit

Design Ratings

Refinery Flare 131,282 MMBTU/yr
(Maximum Refinery Throughput ~35,000 bbl)

Emission Factors

Refinery Flare

NOx	0.068 lb/MMBTU	AP-42 (Table 13.5-1 Emission Factors for Flare Operations)
SO2	26.9 lb/10 ³ bbl	
PM10	137 lb/MMBTU	AP-42 (Table 13.5-1 Emission Factors for Flare Operations)

Emission Calculations

Refinery Flare

NOx: $(131,282 \text{ MMBTU/yr})(0.068 \text{ lb/MMBTU})(\text{Ton}/2000 \text{ lb}) = 4.6 \text{ TPY}$

SO2: $(26.9 \text{ lb SO}_2/1000 \text{ bbl})(35,000 \text{ bbl/day})(365 \text{ day/yr})(\text{Ton}/2000 \text{ lb}) = 172 \text{ TPY}$

PM10: $(137 \text{ ug/L})(\text{g}/10^6 \text{ ug})(\text{lb}/454 \text{ g})(28.32 \text{ g/ft}^3)(212.5 \text{ MMft}^3)(\text{Ton}/2000 \text{ lb}) = 0.9 \text{ TPY}$

FLUID CATALYTIC CRACKING UNIT

Potential To Emit

Design Ratings

FCCU Preheater 75 MMBTU/hr
(Maximum Refinery Throughput ~35,000 bbl)

Emission Factors

FCCU PH

NOx	140 lb/MMscf	AP-42 (Table 1.4-2 Emission Factors for Sox, Nox, CO from Natural Gas Combustion)
SO2	120 PPM	Max. H2S in Fuel Gas
PM10	13.7 lb/MMscf	AP-42 (Table 1.4-2 Emission Factors for Sox, Nox, CO from Natural Gas Combustion)

Emission Calculations

FCCU PH

NOx: $(75 \text{ MMBTU/hr})(\text{MMscf}/450 \text{ MMBTU})(8760 \text{ hr/yr})(140 \text{ lb/MMscf})(\text{Ton}/2000 \text{ lb}) = 102.2 \text{ TPY}$
SO2: $(1460 \text{ MMscf/yr})(120 \text{ ft}^3 \text{ H}_2\text{S/MMscf})(34 \text{ lb H}_2\text{S/lb mol})(\text{lb mol}/379.5 \text{ ft}^3)(64 \text{ lb SO}_2/34 \text{ lb H}_2\text{S})(\text{Ton}/2000 \text{ lb}) = 14.77 \text{ TPY}$
PM10: $(75 \text{ MMBTU/hr})(\text{MMscf}/450 \text{ MMBTU})(8760 \text{ hr/yr})(13.7 \text{ lb/MMscf})(\text{Ton}/2000 \text{ lb}) = 10.0 \text{ TPY}$

FLUID CATALYTIC CRACKING UNIT

Potential To Emit

Design Ratings

FCCU REGEN - Coke Make	5788.7 lbs/hr
	50,709,012 lbs/yr

Emission Factors

FCCU REGEN

NOx	2.41 lbs/1000 lbs Coke Make
SO2	17.35 lb/1000 lbs Coke Make
PM10	7.88 lbs/1000 lbs Coke Make

Emission Calculations

FCCU REGEN

NOx: $(50,709,012 \text{ lbs/yr})(2.41 \text{ lbs/1000 lb})(\text{Ton}/2000 \text{ lb}) = 61 \text{ TPY}$
SOx: $(50,709,012 \text{ lbs/yr})(17.35 \text{ lbs/1000 lb})(\text{Ton}/2000 \text{ lb}) = 440 \text{ TPY}$
PM10: $(50,709,012 \text{ lbs/yr})(7.88 \text{ lbs/1000 lb})(\text{Ton}/2000 \text{ lb}) = 200 \text{ TPY}$

SULFUR RECOVERY UNIT INCINERATOR

Potential To Emit

Design Ratings

Sulfur Recovery Unit 6 Long Tons per Day
21,000 MMBTU/yr Consumption Limit
2.4 MMBTU/yr Maximum Gas Input to the Incinerator

Emission Factors

Sulfur Recovery Unit

NOx	100 lb/MMscf	AP-42 (Table 1.4-2 Commercial Boilers)
SO2	120 ppm/H2S	Fuel Gas Maximum
PM10	12.0 lb/MMscf	AP-42 (Table 1.4-1 Commercial Boilers (4.5 + 7.5))

Emission Calculations

Sulfur Recovery Unit

The SO₂ PTE is a combination of the SO₂ created by converting the tail gas H₂S to SO₂ in the incinerator and the SO₂ created by combustion of the incinerator pilot feed.

Tail Gas

The maximum amount of sulfur leaving the Claus unit is designed to be constant

The amount of sulfur leaving the Claus unit is designed to be 0.42 long tons per day

$$6 \text{ long tons/day} \times (1-0.93) = 0.42 \text{ long tons/day S}$$

Using a conservative assumption of 100% conversion of H₂S to SO₂, this leads to:

$$0.42 \text{ long tons/day} \times 5 \text{ short tons/4.464 long tons} \times 2000 \text{ lb/ton} \times \text{lbmole}/32 \text{ lb S} \times \text{lbmole H}_2\text{S}/\text{lbmole S} = 29.4 \text{ lbmole H}_2\text{S/day}$$

$$29.4 \text{ lbmole H}_2\text{S/day} \times 365 \text{ days/yr} \times 64 \text{ lb SO}_2/\text{lbmole S} \times \text{lbmole SO}_2/\text{lbmole H}_2\text{S} \times \text{ton}/2000 \text{ lb} = 343.4 \text{ ton SO}_2/\text{yr} \text{ -- out of the SRU tail gas incinerator due to tail gas}$$

Pilot Feed

Some SO₂ will also be formed from combustion of the pilot gas fed to the SRU tail gas incinerator.

Btu Rating of SRU tail gas incinerator = 1.95 mmbtu/hr

Refinery gas heat content = 400 Btu/scf

Potential fuel feed to the SRU incinerator:

120 ppmv H₂S in the pilot fuel at a maximum

$$1.95 \text{ mmbtu/hr} \times \text{mmcf}/400 \text{ mmbtu} \times 8760 \text{ hr/yr} = 42.71 \text{ mmcf/yr}$$

This conservatively assumes that the entire feed to the SRU incinerator is fuel gas rather than a mix of fuel gas and tail gas.

$$42.71 \text{ mmcf/yr pilot fuel} \times 120 \text{ ft}^3 \text{ H}_2\text{S}/\text{mmcf} \times \text{lbmole H}_2\text{S}/379 \text{ ft}^3 \times \text{lbmole SO}_2/\text{lbmole H}_2\text{S} \times 64 \text{ lb SO}_2/\text{lbmole S} \times \text{ton}/2000 \text{ lb} = 0.43 \text{ ton SO}_2/\text{yr} \text{ -- From combustion of pilot fuel}$$

$$\text{Total SO}_2: 343.4 + 0.43 = 343.83 \text{ ton SO}_2/\text{yr}$$

LPG Loading/Unloading Flare

Potential To Emit

Design Ratings

Loading of LPG 350,000,000 gal/yr
Heat Input = 404,400 MMBTU/yr

Emission Factors

LPG Loading/Unloading Flare

NOx 0.068 lb/MMBTU AP-42 (Table 13.5-1 Emission Factors for Flare Operations)

Emission Calculations

LPG Loading/Unloading Flare

NOx: $(404,400 \text{ MMBTU/yr})(0.068 \text{ lb/MMBTU})(\text{Ton}/2000 \text{ lb}) = 13.75 \text{ TPY}$

Product Dock Loading

Potential To Emit

Design Ratings

Loading of Product 578,160,000 gal/yr

Capture efficiency = 95%

Emission Factors

Product Dock Loading

NOx 0.068 lb/MMBTU AP-42 (Table 13.5-1 Emission Factors for Flare Operations)

Emission Calculations

Product Dock Loading

$L_L: (8.15 \text{ lb}/1000 \text{ gal})(578,160,000 \text{ gal})(\text{Ton}/2000 \text{ lb}) = 2356 \text{ TPY}$

Quantity Uncaptured: $(2356 \text{ tpy})(0.01\%) = 23.6 \text{ TPY}$

Quantity Flared: $(2356 - 23.6)(0.95) = 2216$

Heat Content Flared: $(2216 \text{ TPY})(2000 \text{ lb}/\text{Ton})(19000 \text{ BTU}/\text{lb}) = 84,208 \text{ MMBTU}/\text{yr}$

NOx: $(84,208 \text{ MMBTU}/\text{yr})(0.068 \text{ lb}/\text{MMBTU})(\text{Ton}/2000 \text{ lb}) = 2.9 \text{ TPY}$

PM: de minimus

SOx: de minimus

Appendix E.5 40CFR Part 60 NSPS Subpart D

Environmental Protection Agency

§ 60.41

TABLE 2 TO SUBPART CE—EMISSIONS LIMITS FOR SMALL HMIWI WHICH MEET THE CRITERIA UNDER § 60.33E(e)

Pollutant	Units (7 percent oxygen, dry basis)	HMIWI emission limits
Particulate matter	Miligrams per dry standard cubic meter (grains per dry standard cubic foot).	197 (0.086).
Carbon monoxide	Parts per million by volume	40.
Dioxins/furans	nanograms per dry standard cubic meter total dioxins/furans (grains per billion dry standard cubic feet) or nanograms per dry standard cubic meter TEQ (grains per billion dry standard cubic feet).	800 (350) or 15 (6.6).
Hydrogen chloride	Parts per million by volume	3100.
Sulfur dioxide	Parts per million by volume	55.
Nitrogen oxides	Parts per million by volume	250.
Lead	Miligrams per dry standard cubic meter (grains per thousand dry standard cubic feet).	10 (4.4).
Cadmium	Miligrams per dry standard cubic meter (grains per thousand dry standard cubic feet).	4 (1.7).
Mercury	Miligrams per dry standard cubic meter (grains per thousands dry standard cubic feet).	7.5 (3.3).

Subpart D—Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced After August 17, 1971

(e) Any facility covered under subpart Da is not covered under this subpart.

[42 FR 37936, July 25, 1977, as amended at 43 FR 9278, Mar. 7, 1978; 44 FR 33612, June 17, 1979]

§ 60.40 Applicability and designation of affected facility.

(a) The affected facilities to which the provisions of this subpart apply are:

(1) Each fossil-fuel-fired steam generating unit of more than 73 megawatts heat input rate (250 million Btu per hour).

(2) Each fossil-fuel and wood-residue-fired steam generating unit capable of firing fossil fuel at a heat input rate of more than 73 megawatts (250 million Btu per hour).

(b) Any change to an existing fossil-fuel-fired steam generating unit to accommodate the use of combustible materials, other than fossil fuels as defined in this subpart, shall not bring that unit under the applicability of this subpart.

(c) Except as provided in paragraph (d) of this section, any facility under paragraph (a) of this section that commenced construction or modification after August 17, 1971, is subject to the requirements of this subpart.

(d) The requirements of §§ 60.44 (a)(4), (a)(5), (b) and (d), and 60.45(f)(4)(vi) are applicable to lignite-fired steam generating units that commenced construction or modification after December 22, 1976.

§ 60.41 Definitions.

As used in this subpart, all terms not defined herein shall have the meaning given them in the Act, and in subpart A of this part.

(a) *Fossil-fuel fired steam generating unit* means a furnace or boiler used in the process of burning fossil fuel for the purpose of producing steam by heat transfer.

(b) *Fossil fuel* means natural gas, petroleum, coal, and any form of solid, liquid, or gaseous fuel derived from such materials for the purpose of creating useful heat.

(c) *Coal refuse* means waste-products of coal mining, cleaning, and coal preparation operations (e.g. culm, gob, etc.) containing coal, matrix material, clay, and other organic and inorganic material.

(d) *Fossil fuel and wood residue-fired steam generating unit* means a furnace or boiler used in the process of burning fossil fuel and wood residue for the purpose of producing steam by heat transfer.

(e) *Wood residue* means bark, sawdust, slabs, chips, shavings, mill trim, and other wood products derived from wood processing and forest management operations.

§ 60.42

(f) *Coal* means all solid fuels classified as anthracite, bituminous, sub-bituminous, or lignite by the American Society and Testing and Materials, Designation D388-77 (incorporated by reference—see §60.17).

[39 FR 20791, June 14, 1974, as amended at 40 FR 2803, Jan. 16, 1975; 41 FR 51398, Nov. 22, 1976; 43 FR 9278, Mar. 7, 1978; 48 FR 3736, Jan. 27, 1983]

§ 60.42 Standard for particulate matter.

(a) On and after the date on which the performance test required to be conducted by §60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any affected facility any gases which:

(1) Contain particulate matter in excess of 43 nanograms per joule heat input (0.10 lb per million Btu) derived from fossil fuel or fossil fuel and wood residue.

(2) Exhibit greater than 20 percent opacity except for one six-minute period per hour of not more than 27 percent opacity.

(b)(1) On or after December 28, 1979, no owner or operator shall cause to be discharged into the atmosphere from the Southwestern Public Service Company's Harrington Station #1, in Amarillo, TX, any gases which exhibit greater than 35% opacity, except that a maximum of 42% opacity shall be permitted for not more than 6 minutes in any hour.

(2) Interstate Power Company shall not cause to be discharged into the atmosphere from its Lansing Station Unit No. 4 in Lansing, IA, any gases which exhibit greater than 32% opacity, except that a maximum of 39% opacity shall be permitted for not more than six minutes in any hour.

[39 FR 20792, June 14, 1974, as amended at 41 FR 51398, Nov. 22, 1976; 42 FR 61537, Dec. 5, 1977; 44 FR 76787, Dec. 28, 1979; 45 FR 36077, May 29, 1980; 45 FR 47146, July 14, 1980; 46 FR 57498, Nov. 24, 1981; 61 FR 49976, Sept. 24, 1996]

§ 60.43 Standard for sulfur dioxide.

(a) On and after the date on which the performance test required to be conducted by §60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be

40 CFR Ch. I (7-1-98 Edition)

discharged into the atmosphere from any affected facility any gases which contain sulfur dioxide in excess of:

(1) 340 nanograms per joule heat input (0.80 lb per million Btu) derived from liquid fossil fuel or liquid fossil fuel and wood residue.

(2) 520 nanograms per joule heat input (1.2 lb per million Btu) derived from solid fossil fuel or solid fossil fuel and wood residue, except as provided in paragraph (e) of this section.

(b) When different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) shall be determined by proration using the following formula:

$$PS_{SO_2} = [y(340) + z(520)] / (y+z)$$

where:

PS_{SO_2} is the prorated standard for sulfur dioxide when burning different fuels simultaneously, in nanograms per joule heat input derived from all fossil fuels fired or from all fossil fuels and wood residue fired.

y is the percentage of total heat input derived from liquid fossil fuel, and

z is the percentage of total heat input derived from solid fossil fuel.

(c) Compliance shall be based on the total heat input from all fossil fuels burned, including gaseous fuels.

(d) [Reserved]

(e) Units 1 and 2 (as defined in appendix G) at the Newton Power Station owned or operated by the Central Illinois Public Service Company will be in compliance with paragraph (a)(2) of this section if Unit 1 and Unit 2 individually comply with paragraph (a)(2) of this section or if the combined emission rate from Units 1 and 2 does not exceed 470 nanograms per joule (1.1 lb per million Btu) combined heat input to Units 1 and 2.

[39 FR 20792, June 14, 1974, as amended at 41 FR 51398, Nov. 22, 1976; 52 FR 28954, Aug. 4, 1987]

§ 60.44 Standard for nitrogen oxides.

(a) On and after the date on which the performance test required to be conducted by §60.8 is completed, no owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any affected facility any gases which contain nitrogen oxides, expressed as NO_x in excess of:

Environmental Protection Agency

§ 60.45

(1) 86 nanograms per joule heat input (0.20 lb per million Btu) derived from gaseous fossil fuel.

(2) 129 nanograms per joule heat input (0.30 lb per million Btu) derived from liquid fossil fuel, liquid fossil fuel and wood residue, or gaseous fossil fuel and wood residue.

(3) 300 nanograms per joule heat input (0.70 lb per million Btu) derived from solid fossil fuel or solid fossil fuel and wood residue (except lignite or a solid fossil fuel containing 25 percent, by weight, or more of coal refuse).

(4) 260 nanograms per joule heat input (0.60 lb per million Btu) derived from lignite or lignite and wood residue (except as provided under paragraph (a)(5) of this section).

(5) 340 nanograms per joule heat input (0.80 lb per million Btu) derived from lignite which is mined in North Dakota, South Dakota, or Montana and which is burned in a cyclone-fired unit.

(b) Except as provided under paragraphs (c) and (d) of this section, when different fossil fuels are burned simultaneously in any combination, the applicable standard (in ng/J) is determined by proration using the following formula:

PS_{Nox} = (w(260)+x(86)+y(130)+z(300)) / (w+x+y+z)

where: PS_{Nox} is the prorated standard for nitrogen oxides when burning different fuels simultaneously, in nanograms per joule heat input derived from all fossil fuels fired or from all fossil fuels and wood residue fired; w= is the percentage of total heat input derived from lignite; x= is the percentage of total heat input derived from gaseous fossil fuel; y= is the percentage of total heat input derived from liquid fossil fuel; and z= is the percentage of total heat input derived from solid fossil fuel (except lignite).

(c) When a fossil fuel containing at least 25 percent, by weight, of coal refuse is burned in combination with gaseous, liquid, or other solid fossil fuel or wood residue, the standard for nitrogen oxides does not apply.

(d) Cyclone-fired units which burn fuels containing at least 25 percent of lignite that is mined in North Dakota,

South Dakota, or Montana remain subject to paragraph (a)(5) of this section regardless of the types of fuel combusted in combination with that lignite.

[39 FR 20792, June 14, 1974, as amended at 41 FR 51398, Nov. 22, 1976; 43 FR 9278, Mar. 7, 1978; 51 FR 42797, Nov. 25, 1986]

§ 60.45 Emission and fuel monitoring.

(a) Each owner or operator shall install, calibrate, maintain, and operate continuous monitoring systems for measuring the opacity of emissions, sulfur dioxide emissions, nitrogen oxides emissions, and either oxygen or carbon dioxide except as provided in paragraph (b) of this section.

(b) Certain of the continuous monitoring system requirements under paragraph (a) of this section do not apply to owners or operators under the following conditions:

(1) For a fossil fuel-fired steam generator that burns only gaseous fossil fuel, continuous monitoring systems for measuring the opacity of emissions and sulfur dioxide emissions are not required.

(2) For a fossil fuel-fired steam generator that does not use a flue gas desulfurization device, a continuous monitoring system for measuring sulfur dioxide emissions is not required if the owner or operator monitors sulfur dioxide emissions by fuel sampling and analysis under paragraph (d) of this section.

(3) Notwithstanding § 60.13(b), installation of a continuous monitoring system for nitrogen oxides may be delayed until after the initial performance tests under § 60.8 have been conducted. If the owner or operator demonstrates during the performance test that emissions of nitrogen oxides are less than 70 percent of the applicable standards in § 60.44, a continuous monitoring system for measuring nitrogen oxides emissions is not required. If the initial performance test results show that nitrogen oxide emissions are greater than 70 percent of the applicable standard, the owner or operator shall install a continuous monitoring system for nitrogen oxides within one year after the date of the initial performance tests under § 60.8 and comply with all other

§ 60.45

40 CFR Ch. I (7-1-98 Edition)

applicable monitoring requirements under this part.

(4) If an owner or operator does not install any continuous monitoring systems for sulfur oxides and nitrogen oxides, as provided under paragraphs (b)(1) and (b)(3) or paragraphs (b)(2) and (b)(3) of this section a continuous monitoring system for measuring either oxygen or carbon dioxide is not required.

(c) For performance evaluations under § 60.13(c) and calibration checks under § 60.13(d), the following procedures shall be used:

(1) Methods 6, 7, and 3B, as applicable, shall be used for the performance evaluations of sulfur dioxide and nitrogen oxides continuous monitoring systems. Acceptable alternative methods for Methods 6, 7, and 3B are given in § 60.46(d).

(2) Sulfur dioxide or nitric oxide, as applicable, shall be used for preparing calibration gas mixtures under Performance Specification 2 of appendix B to this part.

(3) For affected facilities burning fossil fuel(s), the span value for a continuous monitoring system measuring the opacity of emissions shall be 80, 90, or 100 percent and for a continuous monitoring system measuring sulfur oxides or nitrogen oxides the span value shall be determined as follows:

(In parts per million)

Fossil fuel	Span value for sulfur dioxide	Span value for nitrogen oxides
Gas	(¹)	500
Liquid	1,000	500
Solid	1,500	1000
Combinations	1,000y+1,500z	500(x+y)+1,000z

¹ Not applicable.

where:

x=the fraction of total heat input derived from gaseous fossil fuel, and
 y=the fraction of total heat input derived from liquid fossil fuel, and
 z=the fraction of total heat input derived from solid fossil fuel.

(4) All span values computed under paragraph (c)(3) of this section for burning combinations of fossil fuels shall be rounded to the nearest 500 ppm.

(5) For a fossil fuel-fired steam generator that simultaneously burns fossil fuel and nonfossil fuel, the span value of all continuous monitoring systems

shall be subject to the Administrator's approval.

(d) [Reserved]

(e) For any continuous monitoring system installed under paragraph (a) of this section, the following conversion procedures shall be used to convert the continuous monitoring data into units of the applicable standards (ng/J, lb/million Btu):

(1) When a continuous monitoring system for measuring oxygen is selected, the measurement of the pollutant concentration and oxygen concentration shall each be on a consistent basis (wet or dry). Alternative procedures approved by the Administrator shall be used when measurements are on a wet basis. When measurements are on a dry basis, the following conversion procedure shall be used:

$$E=CF[20.9/(20.9-\text{percent O}_2)]$$

where:

E, C, F, and %O₂ are determined under paragraph (f) of this section.

(2) When a continuous monitoring system for measuring carbon dioxide is selected, the measurement of the pollutant concentration and carbon dioxide concentration shall each be on a consistent basis (wet or dry) and the following conversion procedure shall be used:

$$E=CF_c [100/\text{percent CO}_2]$$

where:

E, C, F_c and %CO₂ are determined under paragraph (f) of this section.

(f) The values used in the equations under paragraphs (e) (1) and (2) of this section are derived as follows:

(1) E=pollutant emissions, ng/J (lb/million Btu).

(2) C=pollutant concentration, ng/dscm (lb/dscf), determined by multiplying the average concentration (ppm) for each one-hour period by 4.15x10⁻⁴ M ng/dscm per ppm (2.59x10⁻⁹ M lb/dscf per ppm) where M=pollutant molecular weight, g/g-mole (lb/lb-mole). M=64.07 for sulfur dioxide and 46.01 for nitrogen oxides.

(3) %O₂, %CO₂=oxygen or carbon dioxide volume (expressed as percent), determined with equipment specified under paragraph (a) of this section.

(4) F, F_c=a factor representing a ratio of the volume of dry flue gases generated to the calorific value of the fuel

Environmental Protection Agency

§ 60.45

combusted (F), and a factor representing a ratio of the volume of carbon dioxide generated to the calorific value of the fuel combusted (F_c), respectively. Values of F and F_c are given as follows:

(i) For anthracite coal as classified according to ASTM D388-77 (incorporated by reference—see §60.17), $F=2.723 \times 10^{-17}$ dscm/J (10,140 dscf/million Btu) and $F_c=0.532 \times 10^{-17}$ scm CO_2 /J (1,980 scf CO_2 /million Btu).

(ii) For subbituminous and bituminous coal as classified according to ASTM D388-77 (incorporated by reference—see §60.17), $F=2.637 \times 10^{-17}$ dscm/J (9,820 dscf/million Btu) and $F_c=0.486 \times 10^{-17}$ scm CO_2 /J (1,810 scf CO_2 /million Btu).

(iii) For liquid fossil fuels including crude, residual, and distillate oils, $F=2.476 \times 10^{-7}$ dscm/J (9,220 dscf/million Btu) and $F_c=0.384 \times 10^{-7}$ scm CO_2 /J (1,430 scf CO_2 /million Btu).

(iv) For gaseous fossil fuels, $F=2.347 \times 10^{-7}$ dscm/J (8,740 dscf/million Btu). For natural gas, propane, and butane fuels, $F_c=0.279 \times 10^{-7}$ scm CO_2 /J

(1,040 scf CO_2 /million Btu) for natural gas, 0.322×10^{-7} scm CO_2 /J (1,200 scf CO_2 /million Btu) for propane, and 0.338×10^{-7} scm CO_2 /J (1,260 scf CO_2 /million Btu) for butane.

(v) For bark $F=2.589 \times 10^{-7}$ dscm/J (9,640 dscf/million Btu) and $F_c=0.500 \times 10^{-7}$ scm CO_2 /J (1,840 scf CO_2 /million Btu). For wood residue other than bark $F=2.492 \times 10^{-7}$ dscm/J (9,280 dscf/million Btu) and $F_c=0.494 \times 10^{-7}$ scm CO_2 /J (1,860 scf CO_2 /million Btu).

(vi) For lignite coal as classified according to ASTM D388-77 (incorporated by reference—see §60.17), $F=2.659 \times 10^{-7}$ dscm/J (9,900 dscf/million Btu) and $F_c=0.516 \times 10^{-7}$ scm CO_2 /J (1,920 scf CO_2 /million Btu).

(5) The owner or operator may use the following equation to determine an F factor (dscm/J or dscf/million Btu) on a dry basis (if it is desired to calculate F on a wet basis, consult the Administrator) or F_c factor (scm CO_2 /J, or scf CO_2 /million Btu) on either basis in lieu of the F or F_c factors specified in paragraph (f)(4) of this section:

$$F = 10^{-6} \frac{[227.2 (\text{pct. H}) + 95.5 (\text{pct. C}) + 35.6 (\text{pct. S}) + 8.7 (\text{pct. N}) - 28.7 (\text{pct. O})]}{\text{GCV}}$$

$$F_c = \frac{2.0 \times 10^{-5} (\text{pct. C})}{\text{GCV}(\text{SI units})}$$

$$F = \frac{10^6 [3.64 (\%H) + 1.53 (\%C) + 0.57 (\%S) + 0.14 (\%N) - 0.46 (\%O)]}{\text{GCV}(\text{English units})}$$

$$F_c = \frac{20.0 (\%C)}{\text{GCV}(\text{SI units})}$$

$$F_c = \frac{321 \times 10^3 (\%C)}{\text{GCV}(\text{English units})}$$

(i) H, C, S, N, and O are content by weight of hydrogen, carbon, sulfur, nitrogen, and oxygen (expressed as percent), respectively, as determined on the same basis as GCV by ultimate analysis of the fuel fired, using ASTM method D3178-74 or D3176 (solid fuels) or computed from results using ASTM method D1137-53(75), D1945-64(76), or D1946-77 (gaseous fuels) as applicable.

(These five methods are incorporated by reference—see §60.17.)

(ii) GCV is the gross calorific value (kJ/kg, Btu/lb) of the fuel combusted determined by the ASTM test methods D2015-77 for solid fuels and D1826-77 for gaseous fuels as applicable. (These two methods are incorporated by reference—see §60.17.)

§ 60.46

40 CFR Ch. I (7-1-98 Edition)

(iii) For affected facilities which fire both fossil fuels and nonfossil fuels, the F or F_c value shall be subject to the Administrator's approval.

(6) For affected facilities firing combinations of fossil fuels or fossil fuels and wood residue, the F or F_c factors determined by paragraphs (f)(4) or (f)(5) of this section shall be prorated in accordance with the applicable formula as follows:

$$F = \sum_{i=1}^n X_i F_i \text{ or } F_c = \sum_{i=1}^n X_i (F_c)_i$$

where:
 X_i = the fraction of total heat input derived from each type of fuel (e.g. natural gas, bituminous coal, wood residue, etc.)
 F_i or $(F_c)_i$ = the applicable F or F_c factor for each fuel type determined in accordance with paragraphs (f)(4) and (f)(5) of this section.
 n = the number of fuels being burned in combination.

(g) Excess emission and monitoring system performance reports shall be submitted to the Administrator for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter. Each excess emission and MSP report shall include the information required in § 60.7(c). Periods of excess emissions and monitoring systems (MS) downtime that shall be reported are defined as follows:

(1) *Opacity*. Excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 20 percent opacity, except that one six-minute average per hour of up to 27 percent opacity need not be reported.

(i) For sources subject to the opacity standard of § 60.42(b)(1), excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 35 percent opacity, except that one six-minute average per hour of up to 42 percent opacity need not be reported.

(ii) For sources subject to the opacity standard of § 60.42(b)(2), excess emissions are defined as any six-minute period during which the average opacity of emissions exceeds 32 percent opacity, except that one six-minute average per hour of up to 39 percent opacity need not be reported.

(2) *Sulfur dioxide*. Excess emissions for affected facilities are defined as:

(i) Any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) of sulfur dioxide as measured by a continuous monitoring system exceed the applicable standard under § 60.43.

(3) *Nitrogen oxides*. Excess emissions for affected facilities using a continuous monitoring system for measuring nitrogen oxides are defined as any three-hour period during which the average emissions (arithmetic average of three contiguous one-hour periods) exceed the applicable standards under § 60.44.

[40 FR 46256, Oct. 6, 1975]

EDITORIAL NOTE: For FEDERAL REGISTER citations affecting § 60.45, see the List of CFR Sections Affected in the Finding Aids section of this volume.

§ 60.46 Test methods and procedures.

(a) In conducting the performance tests required in § 60.8, the owner or operator shall use as reference methods and procedures the test methods in appendix A of this part or other methods and procedures as specified in this section, except as provided in § 60.8(b). Acceptable alternative methods and procedures are given in paragraph (d) of this section.

(b) The owner or operator shall determine compliance with the particulate matter, SO₂, and NO_x standards in §§ 60.42, 60.43, and 60.44 as follows:

(1) The emission rate (E) of particulate matter, SO₂, or NO_x shall be computed for each run using the following equation:

$$E = C F_d (20.9) / (20.9 - \% O_2)$$

E = emission rate of pollutant, ng/J (lb/million Btu).

C = concentration of pollutant, ng/dscm (lb/dscf).

%O₂ = oxygen concentration, percent dry basis.

F_d = factor as determined from Method 19.

(2) Method 5 shall be used to determine the particulate matter concentration (C) at affected facilities without wet flue-gas-desulfurization (FGD) systems and Method 5B shall be used to determine the particulate matter concentration (C) after FGD systems.

(i) The sampling time and sample volume for each run shall be at least 60 minutes and 0.85 dscm (30 dscf). The probe and filter holder heating systems in the sampling train may be set to provide a gas temperature no greater than 160 ± 14 °C (320 ± 25 °F).

(ii) The emission rate correction factor, integrated or grab sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The O₂ sample shall be obtained simultaneously with, and at the same traverse points as, the particulate sample. If the grab sampling procedure is used, the O₂ concentration for the run shall be the arithmetic mean of all the individual O₂ sample concentrations at each traverse point.

(iii) If the particulate run has more than 12 traverse points, the O₂ traverse points may be reduced to 12 provided that Method 1 is used to locate the 12 O₂ traverse points.

(3) Method 9 and the procedures in § 60.11 shall be used to determine opacity.

(4) Method 6 shall be used to determine the SO₂ concentration.

(i) The sampling site shall be the same as that selected for the particulate sample. The sampling location in the duct shall be at the centroid of the cross section or at a point no closer to the walls than 1 m (3.28 ft). The sampling time and sample volume for each sample run shall be at least 20 minutes and 0.020 dscm (0.71 dscf). Two samples shall be taken during a 1-hour period, with each sample taken within a 30-minute interval.

(ii) The emission rate correction factor, integrated sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The O₂ sample shall be taken simultaneously with, and at the same point as, the SO₂ sample. The SO₂ emission rate shall be computed for each pair of SO₂ and O₂ samples. The SO₂ emission rate (E) for each run shall be the arithmetic mean of the results of the two pairs of samples.

(5) Method 7 shall be used to determine the NO_x concentration.

(i) The sampling site and location shall be the same as for the SO₂ sample. Each run shall consist of four grab

samples, with each sample taken at about 15-minute intervals.

(ii) For each NO_x sample, the emission rate correction factor, grab sampling and analysis procedure of Method 3B shall be used to determine the O₂ concentration (%O₂). The sample shall be taken simultaneously with, and at the same point as, the NO_x sample.

(iii) The NO_x emission rate shall be computed for each pair of NO_x and O₂ samples. The NO_x emission rate (E) for each run shall be the arithmetic mean of the results of the four pairs of samples.

(c) When combinations of fossil fuels or fossil fuel and wood residue are fired, the owner or operator (in order to compute the prorated standard as shown in §§ 60.43(b) and 60.44(b)) shall determine the percentage (w, x, y, or z) of the total heat input derived from each type of fuel as follows:

(1) The heat input rate of each fuel shall be determined by multiplying the gross calorific value of each fuel fired by the rate of each fuel burned.

(2) ASTM Methods D 2015-77 (solid fuels), D 240-76 (liquid fuels), or D 1826-77 (gaseous fuels) (incorporated by reference—see § 60.17) shall be used to determine the gross calorific values of the fuels. The method used to determine the calorific value of wood residue must be approved by the Administrator.

(3) Suitable methods shall be used to determine the rate of each fuel burned during each test period, and a material balance over the steam generating system shall be used to confirm the rate.

(d) The owner or operator may use the following as alternatives to the reference methods and procedures in this section or in other sections as specified:

(1) The emission rate (E) of particulate matter, SO₂ and NO_x may be determined by using the F_c factor, provided that the following procedure is used:

(i) The emission rate (E) shall be computed using the following equation:

$$E = C F_c (100/\%O_2)$$

where:

E=emission rate of pollutant, ng/J (lb/million Btu).

C=concentration of pollutant, ng/dscm (lb/dscf).

§ 60.40a

%CO₂=carbon dioxide concentration, percent dry basis.

F_c=factor as determined in appropriate sections of Method 19.

(ii) If and only if the average F_c factor in Method 19 is used to calculate E and either E is from 0.97 to 1.00 of the emission standard or the relative accuracy of a continuous emission monitoring system is from 17 to 20 percent, then three runs of Method 3B shall be used to determine the O₂ and CO₂ concentration according to the procedures in paragraph (b) (2)(ii), (4)(ii), or (5)(ii) of this section. Then if F_o (average of three runs), as calculated from the equation in Method 3B, is more than ±3 percent than the average F_o value, as determined from the average values of F_d and F_c in Method 19, i.e., $F_{om}=0.209(F_{dm}/F_{cm})$, then the following procedure shall be followed:

(A) When F_o is less than 0.97 F_{om}, then E shall be increased by that proportion under 0.97 F_{om}, e.g., if F_o is 0.95 F_{om}, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the emission standard.

(B) When F_o is less than 0.97 F_{om} and when the average difference (d) between the continuous monitor minus the reference methods is negative, then E shall be increased by that proportion under 0.97 F_{om}, e.g., if F_o is 0.95 F_{om}, E shall be increased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(C) When F_o is greater than 1.03 F_{om} and when the average difference d is positive, then E shall be decreased by that proportion over 1.03 F_{om}, e.g., if F_o is 1.05 F_{om}, E shall be decreased by 2 percent. This recalculated value shall be used to determine compliance with the relative accuracy specification.

(2) For Method 5 or 5B, Method 17 may be used at facilities with or without wet FGD systems if the stack gas temperature at the sampling location does not exceed an average temperature of 160 °C (320 °F). The procedures of sections 2.1 and 2.3 of Method 5B may be used with Method 17 only if it is used after wet FGD systems. Method 17 shall not be used after wet FGD systems if the effluent gas is saturated or laden with water droplets.

40 CFR Ch. I (7-1-98 Edition)

(3) Particulate matter and SO₂ may be determined simultaneously with the Method 5 train provided that the following changes are made:

(i) The filter and impinger apparatus in sections 2.1.5 and 2.1.6 of Method 8 is used in place of the condenser (section 2.1.7) of Method 5.

(ii) All applicable procedures in Method 8 for the determination of SO₂ (including moisture) are used:

(4) For Method 6, Method 6C may be used. Method 6A may also be used whenever Methods 6 and 3B data are specified to determine the SO₂ emission rate, under the conditions in paragraph (d)(1) of this section.

(5) For Method 7, Method 7A, 7C, 7D, or 7E may be used. If Method 7C, 7D, or 7E is used, the sampling time for each run shall be at least 1 hour and the integrated sampling approach shall be used to determine the O₂ concentration (%O₂) for the emission rate correction factor.

(6) For Method 3, Method 3A or 3B may be used.

(7) For Method 3B, Method 3A may be used.

[54 FR 6662, Feb. 14, 1989; 54 FR 21344, May 17, 1989, as amended at 55 FR 5212, Feb. 14, 1990]

Subpart Da—Standards of Performance for Electric Utility Steam Generating Units for Which Construction is Commenced After September 18, 1978

SOURCE: 44 FR 33613, June 11, 1979, unless otherwise noted.

§ 60.40a Applicability and designation of affected facility.

(a) The affected facility to which this subpart applies is each electric utility steam generating unit:

(1) That is capable of combusting more than 73 megawatts (250 million Btu/hour) heat input of fossil fuel (either alone or in combination with any other fuel); and

(2) For which construction or modification is commenced after September 18, 1978.

(b) This subpart applies to electric utility combined cycle gas turbines that are capable of combusting more

Appendix E.6